

1 Q. Reference: *Refurbish Penstock 2, Bay d'Espoir Generating Station, March 3, 2017,*  
2 Page 2, Line 3.

3

4 *“Anticipated refurbishment of 900 m of penstock weld based upon Penstock 1*  
5 *scope”*

6

7 What is the total length of all welds completed as part of the original construction  
8 of Penstock 1 and what percentage of the total length of Penstock 1 is the 900 m of  
9 weld refurbishment completed in 2016?

10

11

12 A. The total length of all welds completed as part of the original construction is  
13 approximately 7709 m (25,291'). The 900 m of welds refurbished in 2016 is  
14 approximately 11.7% of the total length of penstock welds.