

1 **Undertaking Request (U-23)**

2 **Wednesday, April 25, 2018**

3 **Transcript Reference: Pg. 59, line 22 to Pg. 60, line 12**

4 Undertake to confirm that the load forecast doesn't take into account the possible  
5 requirements of Wabush Mines in 2018 and 2019.

6

7

8 **Undertaking Response**

9 Hydro's Test Year load forecast for Wabush Mines for 2018 and 2019 is 1.2 GWh and 0.0  
10 GWh and 0.3 MW and 0.0 MW of monthly billing demand, respectively. This load forecast  
11 does not reflect the re-opening of the Wabush Mines facility under new ownership.