

1 Q. **(2018 Cost Deferral and Interim Rates Application, Revision 2)** Paragraph 18 of the  
2 Application states “*Hydro is now projecting that the LIL will be capable of*  
3 *transferring 110 MW at a forced outage rate of 30% for 2019.*” Has there been any  
4 change in this projection?

5

6

7 A. The projection of the Labrador-Island Link capability for 2019 has not changed.