

1 Q. **(2018 Cost Deferral Evidence, CA-NLH-5)** The response to CA-NLH-5 states “*Hydro’s*
2 *forecast assumes that testing of the Labrador-Island Link (“LIL”) will begin on*
3 *December 1, 2018. This testing is forecast to result in energy deliveries over the LIL*
4 *during this time.*” Did testing in fact begin on December 1, 2018 and if so, how
5 much energy in kWh has been delivered to the Island over the LIL since
6 December 1, 2018? Is this consistent with projections in the Application?

7

8

9 A. Testing of the LIL started prior to December 1, 2018. Hydro forecast 56 GWh of
10 deliveries over the LIL in December 2018. Testing of the LIL resulted in 43 GWh of
11 actual deliveries in December, a variance of 13 GWh.

12

13 Hydro forecast 69 GWh of deliveries over the LIL for 2018. Hydro achieved 53 GWh
14 of deliveries over the LIL in 2018.