

1 Q. **Load Forecast, Generation, and Purchases**

2 Volume I, section 3.5.3 page 3.28, line 17. Hydro states that TL267 “will enable the
3 delivery of additional capacity to the Avalon Peninsula, relieve congestion, reduce
4 system losses, enhance the resiliency of the current transmission network”. Please
5 indicate if there is any impact from this project to the average hydraulic production
6 forecast?

7

8

9 A. The in-service of TL267 will enable the delivery of more hydraulic energy to the
10 Avalon Peninsula. This will enable more efficient hydraulic unit operation and
11 decreased spill, depending on hydrology and system conditions. However, the
12 impact to the long term annual hydraulic production is expected to be minor.