

1 Q. **Load Forecast, Generation, and Purchases**

2 Further IC-NLH-90 above, please discuss if new transmission line TL267 will
3 eliminate the need for summer Holyrood generation that was used to support
4 Avalon Peninsula transmission system capacity. If so, does the COS methodology for
5 considering past Holyrood usage no longer represent go forward test year
6 expectations with this new asset in place?

7

8

9 A. Summer generation at Holyrood can be required for multiple reasons, including
10 transmission system capacity, line and generation outages, and asset
11 commissioning. While TL267 will reduce the need for summer generation at
12 Holyrood, generation could be required to ensure reliable service for customers.

13

14 With respect to the question on the COS methodology, please refer to Hydro's
15 response to CA-NLH-088.