

1 Q. **References:** (i) IOC-NLH-022, page 2

2

3 Please confirm that the current transmission system in western Labrador is only  
4 constrained in an n-1 configuration? With two conductors the current transmission  
5 lines can supply the entire load?

6

7

8 A. It is confirmed that the current transmission system in western Labrador is only  
9 constrained in an n-1 configuration and that the current system can supply  
10 forecasted load<sup>1</sup> with the two 230 kV transmission lines in-service.

---

<sup>1</sup> Loads forecasted as per Schedule 3-II - Actual and Forecast Electricity Requirements for 2015 to 2019 – Labrador Interconnected System.