

1 Q. **Volume 1 (1<sup>st</sup> Revision), Chapter 3: Operations**

2 Please explain how Hydro calculated the gas turbine production decrease, in GWh,  
3 that results from the introduction of transmission line TL267. (Volume I (1st  
4 Revision), Chapter 3: Operations, Page 3.25, Lines 13-18)

5

6

7 A. Hydro forecast its gas turbine production for this General Rate Application on the  
8 basis of what production would be required for system reserve and production that  
9 would result from testing and exercising the units. As such, Hydro did not calculate  
10 the gas turbine production decrease resultant from the in-service of TL267.