

- 1 Q. **Volume II (1<sup>st</sup> Revision), Exhibit 7: Annual Reports on Key Performance Indicators**  
 2 Please provide a revised table of “Underfrequency Load Shedding Number of  
 3 Events,” as shown on Page 137 of Exhibit 7 that includes the number of events per  
 4 year for the years 2007-2016. (Volume II  
 5 (1st Revision), Exhibit 7: Annual Reports on Key Performance Indicators, Page 137 of  
 6 168)  
 7  
 8  
 9 A. Please refer to Table 1 for the Underfrequency Load Shedding Number of Events for  
 10 the years 2007 to 2016 and Table 2 for a breakdown of the number of events  
 11 experienced per customer for the same period.

**Table 1 Underfrequency Load Shedding - Number of Events**

	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016
Total Events	6	6	7	6	3	5	7	14	8	6

**Table 2 Breakdown of the Customer Experienced Underfrequency Load Shedding Events**

	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016
NF Power	6	6	7	6	3	5	7	14	8	6
Industrials	6	6	5	2	0	1	0	3	6	4
Hydro Rural <sup>1</sup>	6	6	5	0	0	3	3	2	2	1

---

<sup>1</sup> There are two Hydro Rural feeders in the underfrequency load shedding scheme.