

1 Q. **Volume II (1<sup>st</sup> Revision), Exhibit 7: Annual Reports on Key Performance Indicators**

2 In relation to Transmission SAIDI, SAIFI, and SARI, Hydro states:

3 *“The 2016 targets for forced outage performance were not*  
4 *set.”*

5 Please explain how this statement relates to the targets provided for T-SAIDI, T-  
6 SAIFI and T-SARI in the table on Page 110 of Exhibit 7. (Volume II  
7 (1st Revision), Exhibit 7: Annual Reports on Key Performance Indicators, Appendix  
8 A: Rationale for Hydro’s 2016 KPI Targets, Page 150 of 168)

9

10

11 A. The targets listed in the table on Page 110 of Exhibit 7 were calculated using the  
12 combination of planned and forced outages. The statement on Page 150 of Exhibit 7  
13 is incomplete. It should have read as follows: *“The 2016 targets for outage*  
14 *performance were not set with separate target components for forced outages and*  
15 *planned outages, but were set for forced and planned outages combined.”*