

1 A. The information presented in Table 1 is for all Hydro systems, including the
2 Island Interconnected System, the Labrador Interconnected System and Hydro’s
3 Isolated systems. Please note that CEA Region 2 only applies to SAIFI and SAIDI
4 Service Continuity data. For T-SAIFI and T-SAIDI, CEA only records one region, All
5 Canada.

Table 1 Hydro’s Reliability Performance – Ranking in CEA

	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016
SAIDI										
Total Utilities Reporting	14	14	13	14	15	21	21	20	22	22
Hydro’s Ranking	10	11	11	8	14	19	18	19	22	21
SAIFI										
Total Utilities Reporting	14	14	13	14	15	21	21	20	22	22
Hydro’s Ranking	14	14	12	12	14	17	18	17	20	17
T-SAIDI										
Total Utilities Reporting	9	9	10	8	10	10	10	10	10	10
Hydro’s Ranking	8	3	2	4	10	5	8	10	8	8
T-SAIFI										
Total Utilities Reporting	9	9	10	8	10	10	10	10	10	10
Hydro’s Ranking	9	7	4	8	10	8	9	10	9	9