

1 Q. Further to response to Request for Information NP-NLH-044:

2

3 Please restate the tables in the response to correctly identify which data relates to  
 4 forced outages and which data relates to planned outages.

5

6

7 A. Hydro’s response to NP-NLH-044 is restated below.

8

9 The tables show the T-SAIFI and T-SAIDI for planned and forced outages for the  
 10 years 2007 to 2016.

**Table 3-3 (i) Transmission Performance (Unplanned Outages) All Regions**

	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016
<b>T-SAIFI</b>	1.75	0.95	0.38	1.38	3.49	1.32	2.59	2.90	1.53	1.88
<b>T-SAIDI</b>	104.73	63.29	13.53	41.27	220.59	45.54	276.53	214.05	115.65	126.45

**Table 3-3 (ii) Transmission Performance (Planned Outages) All Regions**

	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016
<b>T-SAIFI</b>	1.03	0.74	0.52	0.93	0.98	0.55	0.86	0.88	1.57	0.98
<b>T-SAIDI</b>	81.83	214.81	86.76	132.18	195.13	125.25	191.92	243.66	360.98	198.28

**Table 3-3 (iii) Transmission Performance (Planned and Forced Outages) All Regions**

	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016
<b>T-SAIFI</b>	2.78	1.69	0.90	2.31	4.47	1.87	3.45	3.78	3.10	2.86
<b>T-SAIDI</b>	186.56	278.10	100.29	173.45	415.72	170.79	468.45 <sup>1</sup>	457.71 <sup>2</sup>	476.63	324.73

<sup>1</sup> This change has been addressed in Hydro’s 2017 General Rate Application – Revision 2, filed with the Board on October 16, 2017.

<sup>2</sup> This change has been addressed in Hydro’s 2017 General Rate Application – Revision 2, filed with the Board on October 16, 2017.