

1 Q. Further to response to Request for Information NP-NLH-051:

2

3 Does the forecast production related to system reserve include production required
4 to maintain *Avalon capability and reserve*, as per operating instruction T-096
5 provided in response to Request for Information CA-NLH-106? If so, please provide
6 details (in GWhs and \$) of the production required to maintain *Avalon capability*
7 *and reserve*.

8

9

10 A. The forecast standby production for the 2018 and 2019 Test Years does not include
11 production required to maintain Avalon capability and reserves specifically, but
12 rather to maintain total Island Interconnected System reserves as the in-service of
13 TL267 greatly reduces existing limitations in the transmission corridor from Bay
14 d’Espoir to the Avalon.