

1 Q. **Reference: Summary Report – Additional Cost of Service Information, Section 3.2,**
2 **page 7, Footnote 18**

3

4 In addition to the impact new data centres in Labrador will have on the available
5 Recapture Energy; will additional load from the re-establishment of traditional
6 mining operations in Labrador West have a similar impact on the available
7 Recapture Energy?

8

9

10 A. Yes. Increased customer load requirements on the Labrador Interconnected System
11 will result in a reduction in available Recapture Energy.