

1 Q. **Reference: Supply Cost Deferrals 2015, 2016 and 2017 Application Evidence, Page**
2 **14, lines 1–3 and lines 6-8.**

3

4 *“The data shows that for UFLS events prior to 2014, when Hydro had been operating*
5 *with online reserves lower than the largest online unit, customer restoration times*
6 *of eleven to sixteen minutes for UFLS events were not uncommon.”*

7

8 and

9

10 *“Since implementing a spinning reserve target to cover the loss of Hydro’s largest*
11 *generating unit, customer restoration typically begins within 1-2 minutes and is*
12 *typically complete within 6 minutes.”*

13

14 Is the 5-10 minute reduction in the duration of UFLS events implied in the two cited
15 passages the only benefit to customers of Hydro’s dispatch of standby units in
16 advance of contingencies? If not, please describe the other benefits with reference
17 to specific events.

18

19

20 A. Firstly, as noted in Hydro’s evidence Section 2.5 Alternatives to Hydro’s Approach,
21 page 14, lines 12-20, Hydro notes that had its current operating philosophy not
22 been employed during the period customer restoration times would have increased
23 by an additional 30-40 minutes and a greater number of customers would have
24 been impacted. The 5-10 minute reduction noted in the question does not consider
25 changes to the Island Interconnected System preceding the 2015-2017 period
26 including system load growth, concentration of load on the Avalon Peninsula, and
27 higher unit unavailability, as noted in Hydro’s evidence. If the previous UFLS events

1 (i.e. those with the eleven to sixteen minute restoration time) had happened in the
2 current system without the current operating philosophy, the associated events
3 would have been larger in magnitude and of longer duration.

4
5 The reduction in the duration of UFLS events following unit trips is not the only
6 benefit to customers of Hydro's dispatch of standby units in advance of
7 contingencies, rather another benefit is increased likelihood of avoidance of UFLS
8 events and associated customer impact following unit trips.

9
10 Finally, Hydro's dispatch of generating units to maintain minimum spinning reserve
11 requirements also provides for the inherent benefit of improved response during
12 underfrequency events as there is a reduction in the rate at which system
13 frequency declines. Having fewer units online would result in a faster rate of
14 decline of system frequency. A faster rate of decline of frequency, coupled with
15 slower responding machines, can have the effect of shedding more blocks of
16 customers during underfrequency events. Hydro notes that gas turbines are the
17 fastest to respond to system needs, followed by the Holyrood units, and finally the
18 hydraulic units.