

1 Q. **Reference: Realtime Indication of Island Generating Capacity and Reserves**  
2 **presentation.**

3

4 *“For NLH units and Star Lake, the calculation uses the gross continuous unit ratings*  
5 *which may be adjusted on an operational basis from time to time, to reflect low*  
6 *water levels or inflows, unit availability and temporary unit de-ratings.”*

7

8 Please confirm that, in the calculation of available capacity, on days when both  
9 Holyrood Units 1 and 2 are de-rated, Hydro uses the de-rated value(s) in the  
10 calculation of available capacity. If not, why not?

11

12

13 A. It is confirmed.