

1 Q. Reference: Hydro’s Recovery of the 2015 and 2016 Balances Application,
2 response to Request for Information NP-NLH-016.

3

4 Please update this response to include the average 2017 fuel cost, in ¢/kWh, for
5 operating each of (i) the Holyrood thermal generating station, (ii) the Holyrood GT,
6 (iii) the Hardwoods gas turbine, and (iv) the Stephenville gas turbine.

7

8

9 A. The requested information is included in Table 1.

Table 1 – Average Fuel Cost

| Line No. | Particulars (cents/kWh) | 2015 | 2016 | 2017 |
|----------|--|--------------------|-------|-------|
| 1 | Holyrood Thermal Generating Station ¹ | 11.16 | 7.63 | 11.40 |
| 2 | Holyrood GT ² | 24.83 | 20.66 | 26.53 |
| 3 | Hardwoods GT ² | 47.85 ³ | 25.56 | 32.76 |
| 4 | Stephenville GT ² | 50.86 ³ | 30.76 | 40.63 |

¹ Actual fuel cost/actual conversion rate.

² Actual fuel cost/gross production.

³ The cost per kWh of fuel in this year is materially higher primarily due to a lower average unit loading which resulted in lower overall fuel efficiency of these units.