

1 Q. Further to the response to PUB-NLH-046, please confirm, or correct if necessary,
2 that Hydro maintains the following supply reserves.

3 Spinning Reserve: Capacity of the largest generating unit (170 MW when
4 either Holyrood Unit 1 or Unit 2 is online, otherwise
5 154 MW)

6 Plus

7 Additional Reserve: 70 MW minimum

8 Equals

9 Total Minimum Reserve: 240 MW (with Holyrood Unit 1 or Unit 2), otherwise
10 224 MW

11

12

13 A. It is not confirmed. Hydro's total reserve is 240MW (or 224MW). The 240 MW, with
14 Holyrood Unit 1 or Unit 2, otherwise 224MW, represents Hydro's total reserve, not
15 Hydro's total minimum reserve.