

1 Q. Reference: *Hydro's 2015 & 2016 Supply Cost Recovery Application Evidence*,
 2 *October 11, 2017*, Schedule 1, Appendix F & G.

3

4 For each of 2015 and 2016, please provide the average fuel cost, in ¢/kWh, for
 5 operating each of (i) the Holyrood thermal generating station, (ii) the Holyrood GT,
 6 (iii) the Hardwoods gas turbine, and (iv) the Stephenville gas turbine.

7

8

9 A. The requested information is provided in Table 1.

Table 1 2015 and 2016 Average Fuel Cost

Line No.	Particulars (cents/kWh)	2015	2016
1	Holyrood Thermal Generating Station ¹	11.16	7.63
2	Holyrood GT ²	24.83	20.66
3	Hardwoods GT ²	47.85 ³	25.56
4	Stephenville GT ²	50.86 ³	30.76

¹ Actual fuel cost/actual conversion rate.

² Actual fuel cost/gross production.

³ The cost per kWh of fuel in 2015 is materially higher than 2016 primarily due to a lower average unit loading in 2015 which resulted in lower overall fuel efficiency of these units.