

- 1 **Q. At page 20 of Navigant Consulting Limited ("Navigant") report dated October 31,**
2 **2014, reference is made to the fact that in four jurisdictions in Canada (BC, MB, NS**
3 **and ON) a simplified and expedited process for systems that fall below a given**
4 **capacity is offered. Three of these use a 10 k W limit and the other (BC) uses 27**
5 **kW. Has Newfoundland Power considered implementing a similar simplified and**
6 **expedited process for smaller systems, having regard to the fact that Newfoundland**
7 **Power has stated that it reserves the discretion to limit the size of proposed**
8 **customer generation?**
9
- 10 A. Customers choosing to participate in Newfoundland Power's Net Metering Service
11 Option will be required to complete the Net Metering Interconnection Application Form.¹
12 Once experience is gained in processing customer net metering applications, the
13 Company intends to re-evaluate the application process to determine if an expedited
14 process for small customer owned generating systems is appropriate. This is consistent
15 with the approach of other Canadian jurisdictions.²

¹ Please see Attachment A to the response to Request for Information CA-NP-003 for a copy of Newfoundland Power's Net Metering Interconnection Application Form.

² See Exhibit 1: *Navigant Net Metering Standard Practices Study*, Page 28 of 63.