



OLTHUIS KLEER
TOWNSHEND - LLP

BARRISTERS AND SOLICITORS

Senwung Luk
sluk@oktlaw.com
416.981.9443
416-981-9350
74009

December 21, 2018

The Board of Commissioners of Public Utilities
Ms. G. Cheryl Blundon, Board Secretary
Prince Charles Building
210 - 120 Torbay Road,
St. John's, NL, A1A 2G8

Re: NLH Capital Application (2018) – Labrador Interconnected Group RFIs LAB-NLH-035 to LAB-NLH-067

Please accept the enclosed Requests for Information, served on behalf of the Labrador Interconnected Group.

Should you have any questions, please be sure to contact me.

Respectfully,
Olthuis, Kleer, Townshend LLP
PER:

A handwritten signature in black ink, appearing to read 'Senwung Luk', written over a white background.

SENWUNG LUK
PARTNER

SL/tw

IN THE MATTER OF the *Electrical Power Control Act, 1994*, RSNL 1994, Chapter E-5.1 (the “*EPCA*”) and the *Public Utilities Act*, RSNL 1990, Chapter P-47 (the “*Act*”), and regulations thereunder;

IN THE MATTER OF an Application by Newfoundland and Labrador Hydro for an Order approving:

- 1) its 2018 capital budget pursuant to s.41(l) of the Act;
- 2) its 2018 capital purchases and construction projects in excess of \$50,000 pursuant to s.41(3)(a) of the Act;
- 3) its leases in excess of \$5,000 pursuant to s.41 (3)(b) of the Act;
- 4) its estimated contributions in aid of construction for 2018 pursuant to s.41 (5) of the Act.

IN THE MATTER OF Order No. P.U. 43(2017) in relation to Hydro's 2018 Capital Budget application; and

IN THE MATTER OF additional information filed by Newfoundland and Labrador Hydro pursuant to Order Nos. P.U. 43(2017) and P.U. 9(2018).

Requests for Information

by the Labrador Interconnected Group

LAB-NLH-35 to LAB-NLH-67

December 21, 2018

1 **Requests for Information Regarding the Application for the Proposed Muskrat Falls to**
2 **Happy Valley-Goose Bay Interconnection Project (the “Application”)**

3
4 **Load forecasts**

5 **LAB-NLH-35 Re: Letter from NLH to Board dated November 30, 2018,**
6 **Table 1; 2018 CBA, MFHVI Project, Revision 2, dated January 25,**
7 **2018, p. 13 of the pdf**

8 Preamble :

9 The Labrador East load forecast presented in the Transmission Expansion Study
10 and reproduced as Table 1 is substantially lower than the load forecast presented
11 as Table 1 on page 10 of the MFHVI project document produced as Tab 13 of the
12 2018 CBA. This forecast is identified in the Expansion Study as a P90 forecast,
13 released in July 2018. Compared to the three forecasts shown in Appendix A of
14 that same document (page 27 of the pdf), the current forecast is substantially
15 higher than the Fall 2016 forecast, slightly higher than the Spring 2017 forecast,
16 and substantially lower than the Summer 2017 forecast.

- 17 a) Are the three forecasts in the CBA also P90 forecasts? If not, please specify.
- 18 b) Please explain in detail the reasons behind these multiple changes in the Lab East load
19 forecast, and explain in detail reasons for the reduction noted between the Summer 2017 load
20 forecast and the July 2018 load forecast presented in Table 1 of the November 30 letter.
- 21 c) Has the load forecast been updated since July 2018? If so, please present the most recent
22 Labrador East load forecast.
- 23 d) Please break down each of these forecasts, year by year, between i) loads related to
24 cryptocurrency mining activities (“data centres”), ii) loads related to DND conversion to all-
25 electric boilers and iii) other loads.
- 26 e) The 2018 Base Coincident Peak, according to Table 1 of the Nov. 30 letter, is 81.7 MW.
27 Please indicate actual peak demand for the years 2016, 2017 and 2018, breaking them down
28 into a) loads related to cryptocurrency mining activities (“data centres”), and b) other loads.
- 29 f) Please provide the most recent load forecast, under the hypothesis that all data centre loads
30 are curtailed for the peak 300 hours.

31
32 **LAB-NLH-36 Re: NLH, Attachment 1, Responses to PUB Questions, page 2**

33 Citation:

34 Table 1 provides actual peak demands for the Happy Valley-Goose Bay system since the
35 winter of 2000/2001.

1 The 2017/2018 peak of 66.9 MW (to February 28, 2018) is less than the forecast
2 requirement of 79.9 MW primarily because the connected data centre customer loads
3 have not ramped up to operational load requirements. In addition, the temperatures during
4 system peak periods for the current winter to date have been milder than normal peak
5 period weather conditions for this region.

6 Preamble:

7 Table 1 shows peak loads of 71.1 MW in 2016/17 (the historic high), and of 66.9
8 MW in 2017-18p.

9 a) Please provide the actual peak load in the winter of 2017/18.

10 b) Please provide:

11 i) the forecast peak load in the winter of 2018/19,

12 ii) the forecast peak load in the winter of 2018/19 without the 5.5 MW interruptible
13 contract with Labrador Lynx Ltd.,

14 iii) the forecast peak load in the winter of 2018/19 without any data centre loads, and

15 iv) the forecast peak load in the winter of 2018/19 under the hypothesis that all data
16 centre loads are curtailed for the peak 300 hours of the year.

17
18 **LAB-NLH-37. Re: Letter from NLH to Board dated November 30, 2018, page**
19 **3**

20 Citation:

21 The data shows that while transmission system capacity remains at 77 MW at the
22 25 kV bus in the Happy Valley Terminal Station, the current coincident peak load
23 forecast is above the transmission system capacity.

24 a) Please confirm that, without taking into consideration the temporary 5.5 MW interruptible
25 contract with Labrador Lynx Ltd., Hydro's existing customer base would have a coincident
26 peak load forecast for winter 2018-2019 that is above the transmission system capacity of 77
27 MW.

28 b) Please explain how it came about that Hydro has accepted service requests with peak loads
29 greater than the amounts it is capable of serving reliably with existing infrastructure.

30 c) Is it good utility practice to accept service requests resulting in peak loads greater than the
31 amounts the utility is capable of serving reliably with existing infrastructure? Please provide
32 references in support of your response.

33

1 **LAB-NLH-38 Re: Labrador Expansion Study, p. 18-20 (pdf)**

2 Citation:

3 3.1.1 Labrador East

4 ... Looking forward, the near-term load growth on the system is expected to be
5 primarily driven by general service sales growth associated with recently approved
6 data centre developments. Energy sales to the Department of National Defence's
7 ("DND") large general service account amounts to roughly 30 percent of total general
8 service sales on this system and is expected to remain stable. Potential exists for load
9 increase associated with DND should it convert its central heating plant fuel from oil
10 to electricity. For the longer term, forecasted load growth reflects a return to typical
11 residential customer growth and modest expansion of the area's general service loads.
12 (page 20) (underlining added)

13 ...

14 3.1.2 Labrador West

15 ... Looking forward, the near-term load growth within the region is primarily driven
16 by general service sales growth associated with recently approved data centre
17 developments. Based on expressed interest in data centre developments, the potential
18 for increased general service electricity sales within this region is considered
19 significant. (underlining added)

20 Preamble:

21 Table 3 provides a P90 peak load forecast (released in July 2018).

- 22 a) For both Labrador East and Labrador West, please break down this load forecast, year by
23 year, distinguishing between data centre loads, industrial loads, and other loads.
- 24 b) Please provide an update regarding DND's intentions with respect to the possible
25 conversion of its central heating plant from oil to electricity.
- 26 c) Has Hydro indicated to DND that it may not have sufficient capacity to supply electricity
27 for this purpose during all hours of the year?
- 28 d) In the event that DND decides to proceed with its electric conversion, has Hydro asked
29 DND to consider continuing to use its existing oil-burning boiler during certain hours?
- 30 e) For both Labrador East and Labrador West, please indicate each new customer with a
31 peak load greater than 200 kW that has been added to the Lab West system since 2016,
32 providing for each:
- 33 i. The customer's name (or a unique indicator, if for privacy reasons the name
34 cannot be revealed);
- 35 ii. The location of the premises;
- 36 iii. The date of the service request;

- 1 iv. The peak capacity requested;
- 2 v. The date when the service request was accepted;
- 3 vi. The date when service was initiated; and
- 4 vii. The total billings for each calendar year since service was initiated.

5

6 **LAB-NLH-39. Re: Labrador Expansion Study, p. 21 (pdf), note 14**

7 Citation:

8 In the event Tacora operations do not materialize, the baseline load forecast will not
9 exceed the 350 MW capacity of the existing transmission system. The resulting
10 impacts of such a change in forecast are addressed in sections of this report relating to
11 transmission system expansion plans.

12 Please provide the baseline peak load forecast for Labrador West, without the Tacora loads,
13 distinguishing between data centre loads, industrial loads and other loads.

14

15 **LAB-NLH-40 Re: Letter from NLH to Board dated November 30, 2018,**
16 **pages 3-4, Table 4**

17 Preamble :

18 The table shows commissioning of « Transmission/Muskrat Falls TS2 Expansion »
19 ending in December 2019, and commissioning of « Happy Valley Terminal Station
20 upgrades/expansion » ending in October 2020.

21 Preamble:

22 “Therefore, the transmission line extension and Muskrat Falls TS2 work is scheduled
23 for completion by December 2019, and the Happy Valley work will continue into
24 2020 and be complete by December 2020.” (p3)

25 a) Please break down the total project costs between « Transmission/Muskrat Falls TS2
26 Expansion » and « Happy Valley Terminal Station upgrades/expansion ».

27 b) Please confirm that « the Project » consists of both of these components, and so that the
28 Project will not be fully commissioned until October 2020.

29 Preamble :

30 According to s. 7(b) of the Labrador Settlement Agreement, the Parties agree to
31 « Inclusion of the MF-HV Project in Hydro's closing rate base for the 2019 Test Year,
32 if approved by the Board for construction to be completed in 2019 prior to Hydro's
33 2017 GRA Compliance filing ».

- 1 c) Please explain Hydro's understanding of the implications of this provision and, for greater
2 clarity, indicate the rate base amounts related to the MF-HV Project at the end of 2019, 2020
3 and 2021, under the following hypotheses :
- 4 a. The Board approves the Project in or before February 2019;
- 5 b. Hydro's 2017 GRA Compliance Filing is filed in March and approved in April;
- 6 c. Construction of « Transmission/Muskrat Falls TS2 Expansion » is completed in
7 2019, and
- 8 d. Construction of « Happy Valley Terminal Station upgrades/expansion » is
9 completed in 2020.

10

11 **LAB-NLH-40. Re: LAB-NLH-021**

12 Under these same hypotheses, please provide:

- 13 a) The increase in rate base due to these two components, for the years 2020, 2021, 2022
14 and 2023;
- 15 b) The resulting increase in Labrador revenue requirements for the years 2020, 2021, 2022
16 and 2023;
- 17 c) The annual revenues expected from existing data centre customers in each of the years
18 2020, 2021, 2022 and 2023;
- 19 d) The estimated rate increase for existing customers in each of the years 2020, 2021, 2022
20 and 2023, assuming no load growth other than data centres;
- 21 e) The estimated rate increase for existing customers in each of the years 2020, 2021, 2022
22 and 2023, assuming the load growth described in the load forecast in Table 1 of the Nov.
23 30 letter; and
- 24 f) The estimated rate increase for existing customers in each of the years 2020, 2021, 2022
25 and 2023, assuming the load growth described in the load forecast in Table 1 of the Nov.
26 30 letter but where data centre loads are all curtailed for the peak 300 hours of the year.

27

28 **LAB-NLH-41. Re: Labrador Expansion Study, p. 42 (pdf)**


29 Citation:

30 9 Customer Rate Impacts

31 There is significant uncertainty with respect to specific customer rate impacts
32 associated with the expansion of the transmission system in Labrador. As presented in
33 Section 7, the size and timing of customer requests will have a significant impact on

1 expansion requirements. Further, the application of the Network Addition Policy has
2 the potential to impact cost allocations to ensure fairness. It is only by performing a
3 detailed system impact study in response to a specific customer request that such rate
4 calculations can be performed.

5 For the purposes of this Expansion Study, Figure 6 has been provided as a basis for
6 the generic calculation of forecast rate impacts for rural and industrial customers in
7 Labrador as a function of the capital costs of a transmission system expansion.



8 **Figure 6: Projected Rate Increase vs. Capital Investment**

8

9 Preamble:

10 Figure 6 suggests a linear relationship between capital investment and rate increases.
11 However, given that the transmission expansion projects selected in the study are
12 large and “lumpy”, the relationship between load increases and rate impacts does not
13 follow a straight line.

14 Please present graphs, separately for Labrador East and Labrador West, that indicate:

- 15 a) On the x-axis, peak load,
- 16 b) On the left y-axis, capital expenditures for transmission infrastructure required to meet
17 the peak load on the x-axis, and
- 18 c) On the right y-axis, the % rate increase for rural and industrial customers resulting from
19 those investments.

20

21 **LAB-NLH-42. Re: LAB-NLH-006, page 6, Table 1**

22 Preamble :

23 Table 1 shows that, in 2017, Labrador East load exceeded 70 MW for only 0.25 hours.

- 24 a) Please extend Table 1 to include 2018 (to date).

1 b) Please provide a version of Table 1 for 2017 and 2018 under the assumption that all “data
2 centre” loads are curtailed during the 300 peak hours of the year.

3

4 **LAB-NLH-43. Re: Labrador Expansion Study, pp. 26-27 (pdf)**

5 Citation:

6 A load flow analysis was performed to assess the network of 46 kV transmission lines
7 that supply Hydro Rural customers in Labrador City and Wabush. ...

8 The results of the analysis indicate that transmission lines overloads exist in peak load
9 conditions. To prevent the thermal overloading in the baseline forecast condition, the
10 reconductoring of 46 kV transmission lines L32, L33, and L40 is required. The capital
11 cost associated with this work is estimated to be approximately \$1.4 million. This
12 work will ensure sufficient capacity to meet peak load conditions for the 25-year study
13 period.

14 To prevent overload conditions in the sensitivity forecast condition, the
15 reconductoring noted above, as well as that of L36, is required. The capital cost
16 associated with this work is estimated to be approximately \$1.8 million. This work
17 will ensure sufficient capacity to meet peak load conditions for the 25- year study
18 period.

19 a) Please indicate for how many hours per year these overload conditions are experienced.

20 b) Please indicate for how many hours per year these overload conditions would be
21 experienced, if all existing and future data centre loads were curtailed during the peak 300
22 hours.

23

24 **LAB-NLH-44. Re: LAB-NLH-021**

25 Citation:

26 Q. Please confirm that:

27 a. the service requests that Hydro currently has for Labrador East exceed
28 32 MW including the 8.6 MW for which service contracts are in place.

29 b. the service requests that Hydro currently has for Labrador East exceed
30 the design capacity of the Muskrat Falls to Happy Valley Interconnection
31 as applied for in the present proceeding.

32 c. Hydro has received inquiries for 200 MW in Labrador East. ...

33 A. For item a, the 32 MW of service requests are in addition to the 8.6 MW
34 already committed. Items b and c are confirmed.

35 Please update the information provided in LAB-NLH-021, indicating:

- 1 a) The total capacity of data centre customers in Lab East for which service contracts are
2 in place,
- 3 b) The total capacity of pending requests for service in Lab East, distinguishing between
4 data centres and other types of customers, and
- 5 c) The total capacity for which inquiries have been received for service in Lab East.

6

7 **LAB-NLH-45. Re: PUB-NLH-050, page 1; Letter of Nov. 30, page 4**

8 Citation:

9 In order to maintain the possibility of completing the planned 2018 work, Hydro has
10 commenced the engineering required to support the issuance of tenders for long lead
11 equipment. At this point it is critical to advance the detailed design so that
12 engineering can be completed and tenders for construction contracts prepared. These
13 activities are critical to support a June construction start, which is essential given the
14 short Labrador construction season. Hydro is in a position to award a contract to start
15 the detailed design, and is awaiting Board approval in order to award that contract.
16 Originally, Hydro's plan had detailed engineering beginning at the end of February.
17 At this point, any further delay in starting this critical design element puts pressure on
18 the completion date. If approval is granted around Friday, March 16, 2018, Hydro
19 expects to achieve the in-service date of the interconnection, and the increase in
20 capacity to Labrador East.

21 Preamble:

22 Table 4 in the letter of Nov. 30 indicates that, with planning, design and procurement
23 beginning in February 2019, the project could be commissioned by September 2020.

24 What is the latest date by which the PUB can approve the MFHVI in order to have construction
25 of the MFHVI complete by December 2019? Please provide an explanation as to why this date
26 was chosen.

27

28 **LAB-NLH-46. Re: LAB-NLH-021**

- 29 a) Has Hydro observed any reduction in power consumption by its data centre customers in
30 the last six months? If so, please describe in detail.
- 31 b) Does Hydro have an idea of the bitcoin price threshold below which bitcoin mining in
32 Labrador would not be cost effective? Please elaborate, and disclose any market studies
33 within Hydro's possession on the elasticity of demand of data centre customers as it
34 relates to the price of bitcoin.
- 35 c) Please disclose any forecasts of bitcoin prices that Hydro has in its possession.

- 1 d) Please state Hydro's view as to the factors behind the demand for electricity of data
2 centre customers.
- 3 e) Please disclose any studies Hydro has done or has in its possession regarding the effects
4 of cryptocurrency rates and policies in other jurisdictions (especially North American
5 jurisdictions such as Quebec and New York State) on demand for electricity by
6 cryptocurrency customers in Labrador.
- 7 f) Please disclose all data that Hydro has in its possession on electricity demand by data
8 centre customers in 2017-18 in other jurisdictions.
- 9 g) Please disclose any forecasts that Hydro has in its possession of electricity demand by
10 data centre customers in other jurisdictions.

11

12 **Reliability**

13 **LAB-NLH-47. Re: Labrador East Reliability Plan, Monthly Status Report,**
14 **December 17, 2018, page 2**

15 Citation:

16 **2.3 Inspections of L1301/L1302**

17 Status: Ongoing

18 Progress to Date: Ongoing

19 Hydro has carried out infrared inspection of all line splices on L1301/L1302, with no
20 defective splices discovered. Hydro has carried out several aerial patrols, most
21 recently on November 5, 2018. No additional deficiencies were identified from the
22 last aerial patrol. Patrols will continue at six-week intervals throughout the 2018-2019
23 winter season, with the next patrol scheduled for December 19, 2018.

- 24 a) Have any deficiencies been identified in L1301/L1302 since these regular inspections began?
25 If so, please provide a list of all such deficiencies identified and the corrective measures that
26 were taken.
- 27 b) Given these findings and the ongoing inspection protocol, please provide Hydro's best
28 estimate of the probability of a major outage of the L1301/L1302 during winter 2018/19 and
29 2019/20.
- 30 c) Does Hydro own and operate any other radial transmission lines constructed in the 1970s or
31 earlier? If so, please identify each one, and the refurbishments currently planned (if any),
32 including estimated commissioning date and capital cost.

33

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37

LAB-NLH-50. Re: 2018 CBA, MFHVI Project, Revision 2 (2018-01-25), pages 34-35 (pdf)

Citation 1 (page 14 of pdf):

Five power supply options for the Upper Lake Melville area were analyzed from both a technical and cost benefit point of view. It was shown that while maintaining long term supply from Churchill Falls (status quo) with an additional 125 MVA transformer added at Churchill Falls, a 67 MVAR capacitor bank, and 50MVA transformer at Happy Valley – Goose Bay, had the lowest initial capital cost, it did not have the lowest cumulative net present value. Connection of the Upper Lake Melville to Muskrat Falls via construction of a six km long transmission line from the existing 138 kV right of way to the Muskrat Falls site had the lowest cumulative net present value of the five options.

Preamble:

- i. The capital cost for Option 1 (125 MVA transformer at CF, 65 MVA Capacitor Bank, new 50 MVA transformer at HV) is given as $\$4.05 + \$5.0 + \$3.8 = \12.85 million. O&M costs are given as $\$450\text{k/yr}$. The study assumed an annual one-week maintenance outage of L1301/L1302 for cross-arm replacement, requiring operation of the HV Gas Turbine, at a cost of $\$1.33\text{ M/yr}$. (pages 34-35 of pdf) The analysis shows that, during that one-week maintenance outage, HV (including data centre loads) would occasionally exceed the 25 MW limit of the HVGT.
- ii. Option 2 (the MFHVI project) shows a capital cost of $\$20.0\text{ M}$, and O&M of $\$470\text{k/yr}$. A maintenance outage is required for cross-arm replacement for L1302 only, and the HVGT usage estimate is prorated based on line length and estimated at $\$165.8\text{k/yr}$. Loss savings are estimated at $\$1\text{ M/yr}$ (p. 38 pdf).
- iii. Cumulative NPV is estimated at $\$33,478,915$ for Option 1, and at $\$23,577,661$ for Option 2. (page 54 of pdf)

- a) Please provide detailed calculations showing the derivation of the NPV figures mentioned in Preamble iii), with references and sources for all data and assumptions used.
- b) Please indicate the reduction in NPV for Option 1 that would result if data centre customers were curtailed during the maintenance outage, reducing fuel costs.
- c) Is it possible to reduce the duration of the maintenance outage for cross-arm replacement by committing a large workforce to the task? If so, please indicate the increase in labour cost, and decrease in HVGT operating costs, that would result. If not, please explain why not.

1 Citation:

2 Marginal Cost of Energy: 3.5 cents per kWh.

3 Footnote 26: Nalcor exports surplus energy to the North American grid at a historical
4 profit margin of approximately 3.5 cents per kWh.

5 a) Please confirm that, once the LIL is in operation, the marginal cost of energy for Hydro in
6 Labrador will be equal to the marginal cost of generation at Holyrood, rather than the
7 historical profit margin for sale to the North American grid. If not confirmed, please explain
8 why.

9 b) Please detail the implications for the analysis of using the marginal cost of generation at
10 Holyrood as the marginal cost of generation.

11

12 **LAB-NLH-54. Re: NLH, Attachment 1, Responses to PUB Questions, page 5**

13 Preamble:

14 In response to question 5 of the PUB, Hydro provided an estimate of \$11M over a
15 two-year lease for the use of mobile diesel units to accommodate the forecast 2019
16 peak load of 81.4 MW, including 5 units in 2018 and 6 units in 2019.

17 a) Please estimate the number of diesel units currently forecast to be required to meet
18 2018/2019 peak loads, and provide a cost estimate breakdown specifying:

19 i. rental cost;

20 ii. transportation and installation cost;

21 iii. fuel cost; and

22 iv. any other costs.

23 For fuel costs, please specify:

24 v. estimated generation;

25 vi. estimated fuel required; and

26 vii. estimated unit fuel cost.

27 b) Please provide a similar estimate for 2018/2019 peak loads, under the assumption that all
28 data centre loads are curtailed for the peak 300 hours of the year.

29

30 **LAB-NLH-55. Re: Labrador Expansion Study, p. 11 (pdf)**

1 There appears to be text missing at the end of page 3 of the Study (p. 11 of the pdf). Please
2 complete.

3

4 **LAB-NLH-56. Re: Labrador Expansion Study, p. 14 (pdf); Labrador East**
5 **Reliability Plan Board Update, 2018-12-17**

6 Citation 1 (Labrador Expansion Study):

7 At the North Side Diesel Plant (“NSP”), there is approximately 4 MW of diesel
8 generation; however, due to the deteriorating condition of the plant, it is not reliable as
9 a long term source of capacity.

10 Citation 2 (Labrador East Reliability Plan Update):

11 2.1 Ensure Reliability of the North Plant for Peak Loading Conditions

12 Status: Closed

13 Progress to Date: A third-party service provider for the North Plant Diesels carried out
14 an on site assessment on April 26, 2018. The assessment indicated that the units were
15 not in a condition to guarantee reliable service for the 2018-2019 winter season.
16 Hydro does not anticipate seeking Board approval for capital work related to the
17 North Plant.

18 Preamble:

19 Citation 1 indicates that the NSP is not reliable as a long term source of capacity, and
20 Citation 2 indicates that it is not in a condition to guarantee reliable service for the
21 2018-2019 winter season.

22 a) What is Hydro’s conclusion regarding the NSP’s current status? Is it functional? Can it be
23 operated?

24 b) What are Hydro’s intentions regarding the NSP? Does it intend to decommission it?

25 c) Please provide a summary of the costs that would be required to make the NSP functional i)
26 for the short term, and ii) for the long term.

27

28 **LAB-NLH-57. Re: Labrador Expansion Study, p. 14 (pdf)**

29 When is IOC’s synchronous condenser (SC3) expected to be commissioned? Is its
30 commissioning conditional on other events? Please explain.

31

32 **LAB-NLH-58. Re: Labrador Expansion Study, p. 38 (pdf); Network Addition**
33 **Policy, page 8 (pdf)**

1 Citation 1 (Expansion Study):

Table 10: Labrador East – Proposed Future Phases

Phase	Load Trigger (MW) ³⁰	Project Description	Cost Estimate (\$ million) ³¹
1	>77	MF to HVY Interconnection	20
2	>104	Transformation Upgrade at HVYTS ³²	5
3	>125	Transformation Upgrade at HVYTS and MFATS2 ³³	15
4	>162	Construction of Second Line from MF to HVY	50

2

3 Citation 2 (Network Addition Policy)

Table 1
Derivation of Expansion Costs per kW

Region	Capacity kW	Description	2019 Capital Investment (\$000)	Direct Investment \$ per kW
Labrador East	21,000	Transformer Upgrades at HV-GB	5,000	238
	37,000	Transformer Upgrades at HV-GB and MF Terminal Station	15,000	405
	100,000	Construct second line from MF to HV-GB	50,000	500
Labrador West	33,000	Wabush TS Upgrades and 230 kV uprating	16,500	500
Sub-Total	191,000		86,500	453
		O&M ⁹		12
Total				465

4

5 a) Please confirm that the three expansion projects identified for Labrador East in the
6 Network Addition Policy are identical to the projects identified as Phase 2, 3 and 4 in the
7 table from the Transmission Expansion Study.

8 b) Please explain why the Phase 1 project from the Transmission Expansion Study (the MF
9 to HVY Interconnection) was not included in the derivation of expansion costs in the
10 Network Addition Policy.

11

12 **LAB-NLH-59. Re: Network Addition Policy, page 8 (pdf)**

13 Citation 1:

Table 1
Derivation of Expansion Costs per kW

Region	Capacity kW	Description	2019 Capital Investment (\$000)	Direct Investment \$ per kW
Labrador East	21,000	Transformer Upgrades at HV-GB	5,000	238
	37,000	Transformer Upgrades at HV-GB and MF Terminal Station	15,000	405
	100,000	Construct second line from MF to HV-GB	50,000	500
Labrador West	33,000	Wabush TS Upgrades and 230 kV uprating	16,500	500
Sub-Total	191,000		86,500	453
O&M ⁹				12
Total				465

- 1
- 2 a) Please explain by what process Hydro decided which projects to include in the derivation of
- 3 expansion costs.
- 4 b) Please explain why the MFHVI project is not included in the derivation of expansion costs.
- 5 c) Please explain why the additional expansion projects planned for Labrador West are not
- 6 included in the derivation of expansion costs.

7 **LAB-NLH-60. Re: Network Addition Policy, page 19 (pdf)**

8 Citation:

9 **Transmission Expansion Plan** refers to the most recent transmission system

10 expansion plan for the Labrador Interconnected System filed with the Board. The

11 Transmission Expansion Plan identifies Transmission Upgrades required to serve

12 various load growth scenarios and the estimated costs to implement each upgrade.

13 Please identify which specific elements of the Labrador Transmission Expansion Plan filed with

14 the Board on November 5, 2018 constitute the “Transmission Expansion Plan” for purposes of

15 the Network Addition Policy.

16

17 **LAB-NLH-61. Re: Labrador Expansion Study, p. 31-32 (pdf); Network**

18 **Addition Policy, page 8 (pdf)**

19 Citation 1 (Expansion Study):

20 5.2 Long-Term Supply to Labrador West

21 5.2.1 Transmission System Capacity Upgrades

22 The analysis provided in Appendix B includes a description of the system additions

23 that would be required to increase transmission system capacity in western Labrador

24 to meet the peak baseline forecast of 383 MW.

1 The upgrades include the commissioning of the third synchronous condenser at
 2 Wabush Terminal Station,²³ the installation of an additional 23 MVAR of shunt
 3 compensation, and replacement of transformers T4 and T5 with 125 MVA units.
 4 These upgrade will increase system capacity to meet the baseline peak load forecast of
 5 383 MW.

6 The estimated capital cost of this project is approximated 1 to be \$15.0 million.²⁴

7 Citation 2 (Transmission Expansion Study, page 39 pdf)

8 7.2 Labrador West

9 The existing 230 kV transmission system has a non-firm winter capacity of 350 MW
 10 and is adequate only if supply to industrial customers is restricted. System additions
 11 that would be required to meet the unrestricted baseline load forecast of 383 MW are
 12 described in 5.2.1. Hydro has conducted further analysis to determine the least-cost
 13 options incremental loading scenarios given a significant potential for incremental
 14 load in Labrador West. This comprehensive analysis is provided in Appendix B. Table
 15 11 provides a summary of the preferred alternatives.

Table 11: Preferred Alternative for Incremental Lab West Load Levels

Lab West Load (MW)	Least-Cost Option	Description of Alternative	Capital Cost (\$ million)
> 383	Alternative 5	<ul style="list-style-type: none"> • Commissioning of SC3 • Replacement of T4, T5, and T6 with 125 MVA units for loss of largest transformer • Replacement of four, 46 kV circuit breakers due to exceeding fault level • Installation of 72 MVARs of reactive compensation (needed for loss of SC#3) • Thermal Upgrade of L23/L24 to 75°C conductor temperature 	31.66
> 434	Alternative 17	<ul style="list-style-type: none"> • Construction of 50 km of 315 kV transmission line from Bloom Lake, ("BLK") to Flora Lake ("FLK") and 5 km of 230 kV from FLK to WAB. • BLK 315 kV and WAB 230 kV Line Terminations • Construction of new 315/230/46 kV terminal station at FLK • Installation of four 40.2 MVAR capacitor banks on FLK 230 kV Bus • Commission synchronous condenser SC3 • Upgrade of 14, 46 kV breakers with 2000 A, 31.5 kA breakers • 25 km of new 46 kV distribution lines plus upgrades to existing distribution lines 	153.15

16

17 Citation 3 (Network Addition Policy)

Table 1
Derivation of Expansion Costs per kW

Region	Capacity kW	Description	2019 Capital Investment (\$000)	Direct Investment \$ per kW
Labrador East	21,000	Transformer Upgrades at HV-GB	5,000	238
	37,000	Transformer Upgrades at HV-GB and MF Terminal Station	15,000	405
	100,000	Construct second line from MF to HV-GB	50,000	500
Labrador West	33,000	Wabush TS Upgrades and 230 kV uprating	16,500	500
Sub-Total	191,000		86,500	453
O&M ⁹				12
Total				465

- 1
- 2 a) Please confirm that the single expansion project identified for Labrador West in the Network
3 Addition Policy (Citation 3) is identical to the one identified in the citation from the
4 Transmission Expansion Study (Citation 1).
- 5 b) Please explain why the two projects identified in Table 11 of the Transmission Expansion
6 Study, required if Lab West loads increase beyond 383 MW, were not included in the
7 derivation of expansion costs in the Network Addition Policy.
- 8 c) Please provide an update for the status of the Labrador West Transmission Project (LWTP), a
9 \$330 M, 220-km transmission line between Churchill Falls and Labrador West, and explain
10 why this project is not included in the options reviewed in the Labrador Transmission
11 Expansion Study.
- 12 d) Is Option 17, described on p. 76 as “a new 315 kV line from Bloom Lake to Flora Lake with
13 46 kV Connection from Flora Lake”, at a cost of \$153 M, a replacement for the LWTP?
14 Please explain.

15

16 **LAB-NLH-62. Re: Labrador Expansion Study, p. 40 (pdf)**

17 Citation :

18 7.2.1 Considerations for an Interconnection to Hydro-Québec

19 As per Table 11, if incremental loads are such that forecasted loads in Labrador West
20 exceed 434 MW, the least-cost alternative will involve an interconnection with
21 Hydro-Québec at its Bloom Lake (“BLK”) Station.

22 Hydro has been in consultation with Hydro-Québec TransÉnergie (“HQT”) with
23 respect to interprovincial interconnection alternatives. These discussions have
24 included cooperative transmission planning activities and have allowed for a shared
25 understanding of commercial processes if such an interconnection were to be pursued.

26 From a transmission planning perspective, a preliminary load flow study has been
27 performed cooperatively by personnel from both utilities. The outcome of this

1 analysis is that HQT has validated Hydro's load flow models and analysis and has
2 provided preliminary confirmation of the technical viability of the interconnection.

3 From a commercial standpoint, personnel from HQT have informed Hydro that if the
4 interconnection is to be pursued, a Transmission Service Request will need to be
5 submitted.³⁴ This request will be for a point-to-point service to a new delivery point
6 to be established at the border in western Labrador. This request will trigger the
7 system impact study process.

- 8 a) Please explain Hydro's power supply assumptions with respect to the Hydro-Québec
9 interconnection scenario. Would Hydro purchase electricity from Hydro-Québec, or would it
10 wheel its own power over the HQ transmission system?
- 11 b) In either case, please provide and explain Hydro's estimates of the costs involved.
- 12 c) Please explain why this least-cost option is not included in the derivation of expansion costs
13 (Table 1) in the Network Addition Policy.

14

15 **LAB-NLH-63. Re: Labrador Expansion Study, pages 19 and 73 (pdf)**

16 Preamble:

17 Table 3 (page 19) provides a Baseline Coincident Peak forecast for Labrador West
18 growing from 342.4 MW in 2018 to 382.9 MW in 2043.

19 Table 2 of Appendix B (page 73) shows these same values in the column identified as
20 "baseline peak", and adds separate columns for "Data Centre", rising from 27.1 MW
21 in 2020 to 51.5 MW in 2022 and remaining at that level through 2043, and a final
22 column "Coincident Peak with Alderon", which appears to add 65 MW to the
23 "Coincident Peak with Data Centres" column, from 2022 through 2043.

24 Note 9 specifies that the baseline peak load forecast includes Hydro Rural, IOC and
25 Tacora.

- 26 a) Do the values of "0" for Data Centres in 2018 and 2019 imply that there are no data centre
27 loads included in the Baseline Peak? If not, please specify the amounts of data centre loads
28 that are included in the Baseline Peak column.
- 29 b) Please explain the source and justification for the forecast of data centre loads growing from
30 27.1 MW in 2020 to 51.5 MW in 2022, and remaining at that level through 2043.
- 31 c) Please provide an update on the Alderon project, including Hydro's estimate of the likelihood
32 that it will represent a 65 MW load starting in 2022.

33 **LAB-NLH-64. Re: Labrador Expansion Study, p. 79 (pdf)**

34 Citation:

Table 5: Overview of CPW of Preferred Alternatives and Transfer Capacity

Alt	Description	Forecast (MW)	Winter Firm Capacity (MW)	Non-Firm Capacity (MW)	Estimated Cost (\$ million)	CPW (\$ million)
4	WTS Upgrades (Baseline)	383	252	387	15.1	13.2
5	WTS Upgrades (Low Incremental)	434	252	454	31.7	27.6
17	315 kV Transmission Line from BLK to FLK with 46 kV connection from FLK	499	499	600	153.2	148.1

1
2 Please explain the correspondence between the three projects listed here and those found in
3 Table 1 (Expansion Cost Derivation) of the Network Addition Policy.

4

5 **LAB-NLH-65. Re: Network Addition Policy, page 20 (pdf)**

6 Citation:

7 This section will apply to determine the required Upstream Capacity Charge to supply
8 demand requests of greater than 200 kW from an Applicant.

- 9 a) Please confirm that, for demand requests of up to 200 kW from an Applicant, there is not
10 Upstream Capacity Charge.
- 11 b) Please explain what tools, if any, are available to Hydro if it suspects that two or more
12 demand requests of under 200 kW are from related companies.

13

14 **LAB-NLH-66. Re: Network Addition Policy, pages 21-22 (pdf)**

15 Citation:

16 Upon receipt of an Applicant's Demand request of 1500 kW or greater, Hydro will
17 conduct a preliminary assessment to determine if compliance with the request would
18 require acceleration of the Transmission Expansion Plan.

19 If acceleration of the Transmission Expansion Plan is required, Hydro will determine
20 the Expansion Advancement Cost. This cost reflects the difference between the cost of
21 acceleration of the Transmission Expansion Plan and the value to existing Customers
22 from plan acceleration. The value to existing Customers will be determined based the
23 forecast reduction in Expected Unserved Energy resulting from the capital

1 advancement. However, the credit provided based on the Expected Unserved Energy
2 value to Customers will not exceed 50% of the cost of acceleration of the
3 Transmission Expansion Plan. The procedures used to determine the Expansion
4 Advancement Cost are provided in Appendix B to this Policy.

5 The Upstream Capacity Charge will then be computed as the Expansion Advancement
6 Cost less the Basic Capacity Investment Credit and, when applicable, less the Demand
7 Revenue Credit.

- 8 a) Please explain what baseline will be used for the timing of the Transmission Expansion Plan,
9 in order to determine whether or not a project results in its acceleration.
- 10 b) Please provide a numerical example of the computation of the Upstream Capacity Charge for
11 a project of more than 1500 kW which results in acceleration of the Transmission Expansion
12 Plan.

13

14 **LAB-NLH-67. Re: Network Addition Policy**

15 Preamble:

16 Because the increments of transmission expansion projects are “lumpy”, it is possible
17 that a relatively small demand request may result in the need to proceed with a
18 relatively large expansion project.

19 For a hypothetical situation where a 5 MW demand request results in a \$20 M expansion project,
20 please estimate:

- 21 a) the Upstream Capacity Charge that would be required of the customer,
22 b) the resulting annual revenue requirement increase,
23 c) the annual revenue requirement increase that would be borne by existing customers, and
24 d) the resulting average rate increase, once the capital cost is fully included in rate base.