
1 Q. **Holyrood Overview**

2 If the Holyrood plant is expected to continue to have a base loading function from
3 2022 onwards, has Hydro, in its Capital Plan, taken fully into account the capital
4 projects necessary or prudent to maintain that function from 2022 onwards? If not,
5 what are the capital projects that can be foreseeably expected to be necessary or
6 prudent to maintain Holyrood's base loading function from 2022 onwards?

7

8

9 A. The Holyrood Thermal Generating Station is not expected to have any generating
10 function from 2022 onwards, and therefore there are no capital projects in the plan
11 to maintain the generation function during Phase 3 of the operation. At a minimum,
12 extending generation beyond 2021 would require the continuation of capital
13 projects for turbine, generator, and major pump overhauls in accordance with the
14 established intervals.