

1 Q. **Reference: Letter from NLH to the Board, dated November 30, 2018**

2 Supply

3 Confirm that NLH has access to 29 MW of peak generation on the Labrador East
4 Transmission System, i.e. 25 MW from the Happy-Valley Gas Turbine and 4 MW
5 from the North Side Diesel Plant. Indicate if NLH has access to any addition source
6 of peak generation, whether currently contracted or not.

7

8

9 A. Newfoundland and Labrador Hydro confirms that it has access to 29 MW of peak
10 generation on the Labrador East Transmission System, 25 MW from the Happy
11 Valley Gas Turbine and 4 MW from the North Side Diesel Plant. Assessment of the
12 plant has indicated that the units were not in a condition to guarantee reliable
13 service for the 2018-2019 winter season; however, it is currently in operation.
14 Newfoundland and Labrador Hydro does not have access to any additional source
15 of peak generation.