

1 Q. Re: LAB-NLH-006, page 6, Table 1

2

3 Preamble :

4 Table 1 shows that, in 2017, Labrador East load exceeded 70 MW for only 0.25
5 hours.

6

7 a) Please extend Table 1 to include 2018 (to date).

8 b) Please provide a version of Table 1 for 2017 and 2018 under the assumption
9 that all “data centre” loads are curtailed during the 300 peak hours of the year.

10

11

12 A. Newfoundland and Labrador Hydro believes that this Request for Information was
13 intended to refer to LAB-NLH-008 and responds accordingly.

14

15 a) Please refer to Table 1.

Table 1: Time Exceeding Specific Demand Levels

Load Level (MW)	Hours					
	2013	2014	2015	2016	2017	2018 ¹
>70MW	0	2.75	10.75	0	0.25	0
>69MW	0.25	20.75	21.25	0.25	0.5	0
>68MW	3.25	43.25	39.25	1	0.5	0
>67MW	7.75	58.5	64	1.5	1.5	0
>66MW	17.75	66	93	2.25	5.75	2
>65MW	32.5	87.5	143	3	9.5	6

16 b) Please refer to Table 2 where data centre load is curtailed during the peak
17 hours.

¹ To December 20, 2018

**Table 2: Time Exceeding Specific Demand Levels
(data centre load curtailed during peak hours)**

Load Level (MW)	Hours	
	2017	2018 ²
>70MW	0	0
>69MW	0	0
>68MW	0	0
>67MW	0	0
>66MW	0	0
>65MW	0	0

² To December 20, 2018.