

1 Q. **Re: 2018 CBA, MFHVI Project, Revision 2 (2018-01-25), pages 34-35 (pdf)**  
2 Citation 1 (page 14 of pdf):  
3 Five power supply options for the Upper Lake Melville area were analyzed  
4 from both a technical and cost benefit point of view. It was shown that  
5 while maintaining long term supply from Churchill Falls (status quo) with  
6 an additional 125 MVA transformer added at Churchill Falls, a 67 MVAR  
7 capacitor bank, and 50MVA transformer at Happy Valley – Goose Bay, had  
8 the lowest initial capital cost, it did not have the lowest cumulative net  
9 present value. Connection of the Upper Lake Melville to Muskrat Falls via  
10 construction of a six km long transmission line from the existing 138 kV  
11 right of way to the Muskrat Falls site had the lowest cumulative net  
12 present value of the five options.

13

14 Preamble:

- 15 i. The capital cost for Option 1 (125 MVA transformer at CF, 65 MVA Capacitor  
16 Bank, new 50 MVA transformer at HV) is given as  $\$4.05 + \$5.0 + \$3.8 = \$12.85$   
17 million. O&M costs are given as  $\$450\text{k/yr}$ . The study assumed an annual one-  
18 week maintenance outage of L1301/L1302 for cross-arm replacement, requiring  
19 operation of the HV Gas Turbine, at a cost of  $\$1.33 \text{ M/yr}$ . (pages 34-35 of pdf)  
20 The analysis shows that, during that one-week maintenance outage, HV  
21 (including data centre loads) would occasionally exceed the 25 MW limit of the  
22 HVGT.
- 23 ii. Option 2 (the MFHVI project) shows a capital cost of  $\$20.0 \text{ M}$ , and O&M of  
24  $\$470\text{k/yr}$ . A maintenance outage is required for cross-arm replacement for  
25 L1302 only, and the HVGT usage estimate is prorated based on line length and  
26 estimated at  $\$165.8\text{k/yr}$ . Loss savings are estimated at  $\$1 \text{ M/yr}$  (p. 38 pdf).
- 27 iii. Cumulative NPV is estimated at  $\$33,478,915$  for Option 1, and at  $\$23,577,661$   
28 for Option 2. (page 54 of pdf)

**2018 Capital Budget Application – Muskrat Falls to Happy Valley Interconnection Project**

1 a) Please provide detailed calculations showing the derivation of the NPV figures  
2 mentioned in Preamble iii), with references and sources for all data and  
3 assumptions used.

4 b) Please indicate the reduction in NPV for Option 1 that would result if data  
5 centre customers were curtailed during the maintenance outage, reducing fuel  
6 costs.

7

8

9 A.

10 a) Detailed figures, data, and assumptions used for the cumulative net present  
11 value (“NPV”) analysis are provided in Revision 2 of the “Muskrat Falls to Happy  
12 Valley Interconnection” report, Appendix A “Eastern Labrador Transmission  
13 System Planning Report,” Section 8, Appendices I and J.

14

15 The Cost Benefit Analysis provided in Section 8 includes a high level scope of the  
16 proposed option, the associated capital investment cost, the operation and  
17 maintenance (“O&M”) costs, and assumptions. A summary of results is provided  
18 in Section 8, Table 2.

19

20 Supporting details for all figures provided in Section 8 can be found in Appendix  
21 I and Appendix J. Appendix I contains a detailed summary of operation and  
22 maintenance cost assumptions (for all major assets associated with each  
23 technical alternative). Appendix J contains detailed cash flow tables, which  
24 summarize annual O&M costs, capital costs, as well as all other costs and  
25 benefits associated with each alternative. Cash flows for Option 1 and Option 2  
26 are presented in Tables J.1 and J.2, respectively. These values are the inputs to  
27 perform the NPV analysis presented in Section 8, Table 2.

1           b) Newfoundland and Labrador Hydro does not have the authority to curtail  
2           customers in this fashion. Therefore, the calculations necessary to provide this  
3           information have not been made as such an exercise will not contribute to the  
4           value of the current proceeding.