

1 Q. **Tab 2; Volume II: Increase Fuel & Water Treatment System Capacity**

2 What is the plan for the Holyrood Gas Turbine during the Standby Production Phase  
3 and after interconnection?  
4

5

6

7 A. The plan for the Holyrood Gas Turbine does not change during the Standby  
8 Production Phase and after interconnection. The unit will continue to be utilized as  
9 outlined in Hydro's application. After interconnection, the unit is expected to be  
10 required for purposes similar to current function, such as for spinning reserve, in  
11 advance of single-worst contingency or for generation during unplanned outages.  
12 The unit can also provide on-island capacity in the low probability event of a failure  
on the Labrador Island Link.