

1 Q. **Tab 18; Volume II: Overhaul Diesel Engines (2018)**

2 On page 2, Hydro states that a comprehensive internal maintenance review was  
3 completed in 2003. Has any further review of the diesel engine overhaul criterion  
4 been undertaken by Hydro since 2003? If yes, please provide the analysis. If not,  
5 does Hydro plan to conduct such a review in the future?  
6  
7

8 A. No further comprehensive internal maintenance review has been undertaken since  
9 2003. However, Hydro reviews engine overhaul and maintenance criterion on an  
10 ongoing basis. These ongoing reviews take original equipment manufacturer  
11 recommendations, Hydro engineering and Long Term Asset Planner guidance, and  
12 operational feedback into consideration to make any necessary modifications to  
13 maintenance procedures or frequencies to ensure continued, reliable operation of  
14 diesel generating assets.  
15

16 Hydro is not planning further formal comprehensive internal maintenance reviews;  
17 however, through the normal maintenance review process, if changes are  
18 proposed, a review is completed involving all stakeholders prior to the  
19 implementation of new maintenance strategies.