1	Q.	Please provide support for the total direct expenditure required for the construction of a
2		peaker plant used in the equivalent peaker calculation.
3		
4		
5	A.	Newfoundland and Labrador Hydro based its total direct expenditure required for a peaker
6		plant on the figures provided in the "Reliability and Resource Adequacy Study," Vol III, at p
7		45. Please refer to PUB-NLH-017, Attachment 1 for the report excerpt.

## 4.9 Simple-Cycle Gas Turbine<sup>33</sup>

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

Four GT plant alternatives have been considered. These nominal 66 MW (58.5 MW net), simple-cycle GTs would be located either adjacent to the existing unit at the Holyrood site or at greenfield locations. GTs considered are light oil-fired and, given the unit efficiency, are primarily intended for peaking and voltage support functions. The option considered includes fuel storage capacity to run continuously for a minimum of five days. While these units are considered to support capacity-driven requirements, each is capable of providing approximately 460 GWh of firm energy capability annually. Table 9 provides a summary of the GT alternatives considered.

**Table 9: Gas Turbine Alternatives** 

Туре	Number of Units	Net Capacity (MW)	Capital Cost (\$ million)
Simple Cycle Plant	1	58.5	169
Simple Cycle Plant	2	117	298
Simple Cycle Plant	4	234	664

A preliminary analysis of the transmission requirements and associated single line diagrams were prepared for the purpose of cost estimates for each GT plant alternative.

Environmental considerations for the facilities contemplated have been analyzed, including required emissions control, plant location, and local traffic impact, among other things.

A class 5 capital cost estimate was derived for these units, including include cost of transmission system requirements, operation and maintenance costs, and land price for greenfield sites.

The overall project schedule is estimated to take between 24 to 36 months from the application to the Board to the in-service date.

<sup>&</sup>lt;sup>33</sup> For further details on GT options considered, please refer to Volume III, Attachment 14 "Gas Turbine Alternatives."