

1 Q. **Reference: Study, page 1**

2

3 Please provide the breakdown of the 2019 load forecast of 358 MW for Labrador West
4 between consumers' rate classes. Provide the same for the years 2020, 2021, 2022, 2023
5 and 2043.

6

7

8 A. Table 1 provides the requested breakdown of forecast Labrador West load by rate class. It
9 should be noted that Hydro Rural reflects the forecast P90 baseline requirements.

Table 1: Forecast Labrador West Load (MW)

Year	Hydro Rural	Industrial	Total
2019	81.2	277.2	358.4
2020	81.9	287.1	369.0
2021	82.1	295.0	377.1
2022	82.3	295.0	377.3
2023	82.6	295.0	377.6
2043	87.9	295.0	382.9