

1 Q. **Reference: Network Addition Policy, page 7 of 23 (page 20 pdf)**

2 Citation:

3

4 This section will apply to determine the required Upstream Capacity Charge to
5 supply demand requests of greater than 200 kW from an Applicant.

6

7 a) Please confirm that, for demand requests of up to 200 kW from an Applicant, there is
8 no Upstream Capacity Charge.

9

10 b) Please explain what tools, if any, are available to Hydro if it suspects that two or more
11 demand requests of under 200 kW are from related companies.

12

13

14 A. a) As stated in the “Labrador Interconnected System Network Additions Policy Summary
15 Report,” Sec. 2.3.1, there is no Upstream Capacity Charge required for requests for service
16 of up to 200 kW.

17

18 b) As stated in the “Labrador Interconnected System Network Additions Policy Summary
19 Report,” Sec. 2.3.1, in certain circumstances, Newfoundland and Labrador Hydro may
20 consider multiple applications for 200 kW or less to be one application for a cumulative
21 demand request in excess of 200 kW. The determination of whether multiple applications
22 for service will be treated as a single application will depend on the information provided
23 by the customer in completing an application for service.