

1 Q. Please advise, if there is no separate rate class and the Industrial Customer rate class doesn't
2 apply, which rate class will be used for cryptocurrency customers.

3

4

5 A. Newfoundland and Labrador Hydro's Rural rate classes on the Labrador Interconnected System
6 are based on the customers annual peak demand requirements (i.e., General Service Rate 2.1L
7 0-10 kW, General Service Rate 2.2L 10-100 kW (110 kVA), General Service Rate 2.3L 110 kVA(100
8 kW) -1000 kVA and General Service Rate 2.4L 1000 kVA and Over). The General Service rate to
9 be used in billing cryptocurrency customers depends on their maximum annual peak demand.
10 For example, a cryptocurrency customer with a 500 kVA demand requirement would be billed
11 on Rate 2.3L (i.e., the same as any other General Service customer with a 500 kVA demand
12 requirement).