

- 1 **Q. Please provide in tabular format a list of interruptions to Curtailable Service**
 2 **customers for each of the last five winter periods, including: date of dispatch, time**
 3 **of dispatch, time of recall, amount of load dispatched, and reason for dispatch**
 4 **including whether NP- or Hydro-initiated.**
 5
 6 A. Table 1 provides the requested information with respect to curtailment requests to
 7 customers on the Curtailable Service Option for each of the last 5 winter seasons.
 8

Table 1
Dispatch of Customer Curtailable Load

Date	Curtail Period		Dispatched Load (MW)	Initiated By
	Start	End		
December 6, 2017 ¹	9:00am	10:30am	11.0	NP (Curtailable Test)
March 12, 2017	12:45pm	6:45pm	11.4	Hydro
February 13, 2017	5:00pm	7:30pm	11.0	Hydro
February 7, 2017	4:30pm	8:00pm	11.4	Hydro
December 14, 2016	9:30am	11:00am	10.5	NP (Curtailable Test)
February 24, 2016	8:00am	10:00am	11.6	Hydro
February 3, 2016	7:00am	9:30am	11.3	Hydro
February 3, 2016	4:00pm	6:00pm	10.7	Hydro
January 8, 2016	7:30am	9:30am	10.6	Hydro (Avalon-only)
January 8, 2016	4:00pm	6:30pm	10.2	Hydro (Avalon-only)
January 6, 2016	7:30am	9:00am	8.2	Hydro
January 6, 2016	4:30pm	5:45pm	10.0	Hydro (Avalon-only)
December 8, 2015	9:30am	11:00am	10.6	NP (Curtailable Test)
March 13, 2015	7:00am	10:00am	10.5	Hydro
March 4, 2015	8:15am	11:30am	11.1	Hydro
December 18, 2014	9:30am	11:00am	9.7	NP (Curtailable Test)
March 5, 2014	7:00am	9:30am	7.4	Hydro
March 5, 2014	4:00pm	8:00pm	7.0	NP
January 3, 2014	7:30am	1:30pm	7.0	Hydro
January 3, 2014	4:00pm	9:00pm	7.7	Hydro
January 2, 2014	4:00pm	9:00pm	8.5	Hydro
January 1, 2014	4:30pm	6:30pm	7.1	NP
December 30, 2013	12:00pm	2:00pm	5.0	Hydro
December 30, 2013	4:00pm	6:30pm	7.4	Hydro
December 29, 2013	4:30pm	7:45pm	7.3	Hydro
December 14, 2013	5:00pm	8:00pm	7.2	NP

¹ During the 2017/18 winter season, there were no curtailment requests other than the Curtailment Test.

December 13, 2013 4:30pm 6:30pm 7.2 NP

1 Since the 2014-2015 winter season, Newfoundland Power has requested customers to curtail
2 only when curtailment was requested by NL Hydro, with the exception of the required
3 Curtailable Test early in each season.² Prior to this, Newfoundland Power requested
4 customers to curtail either when Newfoundland Power is approaching a winter peak
5 demand, or when NL Hydro requires curtailments during the winter season to meet system
6 requirements.
7

² In the fall of 2014, the Board approved Hydro's proposal to use a curtailment credit in determining the demand charge to Newfoundland Power.