

- 1 **Q. With regard to NP thermal generation, please provide a table showing the following**
2 **for each of the past five years: date of dispatch, time of dispatch, time of recall,**
3 **amount of generation dispatched, and reason for dispatch including whether NP- or**
4 **Hydro-initiated.**
5
6 A. Please see Attachment A for the requested information relating to Newfoundland Power's
7 thermal generation dispatch for each of the past five years.¹

¹ For the mobile generators, the Mobile Gas Turbine and the Mobile Diesel, the information requested is not always retained when these units are operating in remote locations with multiple starts and stops on a daily basis. In these situations only the date of dispatch is provided.

Newfoundland Power Thermal Generation
2013 - 2017

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
PAB G10	8-Jan-13	10:53 AM	8-Jan-13	11:30 AM	2.8	Testing	Monthly test run
Mobile GT	10-Jan-13	9:25 AM	10-Jan-13	10:19 AM	5.5	Testing	Monthly test run
Mobile GT	11-Jan-13	2:35 PM	11-Jan-13	9:39 PM	6.0	NL Hydro Request	All available generation
Wesleyville GT	11-Jan-13	8:32 AM	12-Jan-13	9:55 AM	10.1	NL Hydro Request	All available generation
Greenhill GT	11-Jan-13	8:39 AM	11-Jan-13	9:40 AM	9.6	NL Hydro Request	All available generation
Mobile GT	11-Jan-13	9:10 AM	11-Jan-13	11:30 AM	2.5	NL Hydro Request	All available generation
PAB G10	11-Jan-13	10:43 AM	11-Jan-13	11:12 AM	1.5	NL Hydro Request	All available generation
PAB G10	11-Jan-13	4:27 PM	11-Jan-13	9:38 PM	1.5	NL Hydro Request	All available generation
Greenhill GT	11-Jan-13	12:24 PM	12-Jan-13	8:47 AM	19.2	NL Hydro Request	All available generation
Mobile Diesel	17-Jan-13	2:09 PM	17-Jan-13	2:37 PM	1.2	Testing	Test run at Whitbourne
Greenhill GT	18-Jan-13	4:44 PM	18-Jan-13	6:57 PM	10.6	NL Hydro Request	BDE Unit off line
Wesleyville GT	18-Jan-13	4:54 PM	18-Jan-13	6:35 PM	8.6	NL Hydro Request	BDE Unit off line
Mobile Diesel	19-Jan-13	5:10 PM	19-Jan-13	6:59 PM	2.4	NL Hydro Request	All available generation
Wesleyville GT	19-Jan-13	8:32 AM	19-Jan-13	8:52 AM	2.0	NL Hydro Request	All available generation
Greenhill GT	19-Jan-13	9:30 AM	19-Jan-13	11:25 AM	19.9	NL Hydro Request	All available generation
Wesleyville GT	19-Jan-13	9:51 AM	19-Jan-13	11:47 AM	8.5	NL Hydro Request	All available generation
Wesleyville GT	19-Jan-13	4:49 PM	19-Jan-13	7:04 PM	8.5	NL Hydro Request	All available generation
Greenhill GT	19-Jan-13	5:54 PM	19-Jan-13	7:16 PM	17.4	NL Hydro Request	All available generation
Greenhill GT	23-Jan-13	4:50 PM	23-Jan-13	5:55 PM	15.2	NL Hydro Request	All available generation
Mobile Diesel	24-Jan-13	4:30 PM	24-Jan-13	8:18 PM	2.3	NL Hydro Request	All available generation
Greenhill GT	24-Jan-13	3:10 PM	24-Jan-13	4:00 PM	19.4	NL Hydro Request	All available generation
Wesleyville GT	24-Jan-13	4:31 PM	24-Jan-13	8:20 PM	8.3	NL Hydro Request	All available generation
PAB G10	24-Jan-13	4:23 PM	24-Jan-13	8:14 PM	2.5	NL Hydro Request	All available generation
Greenhill GT	24-Jan-13	7:01 PM	24-Jan-13	7:03 PM	5.6	NL Hydro Request	All available generation
PAB G10	25-Jan-13	5:03 PM	25-Jan-13	6:28 PM	2.7	NL Hydro Request	All available generation
Greenhill GT	25-Jan-13	5:46 AM	25-Jan-13	6:17 AM	5.9	Testing	Speed pickup replaced
Greenhill GT	25-Jan-13	11:25 AM	25-Jan-13	1:52 PM	5.8	Testing	Black start test
Greenhill GT	25-Jan-13	3:10 PM	25-Jan-13	9:13 PM	20.6	NL Hydro Request	All available generation
Mobile Diesel	25-Jan-13	5:03 PM	25-Jan-13	6:35 PM	2.3	NL Hydro Request	All available generation
Wesleyville GT	25-Jan-13	5:08 PM	25-Jan-13	6:33 PM	8.3	NL Hydro Request	All available generation

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Mobile Diesel	28-Jan-13	4:00 PM	28-Jan-13	6:15 PM	2.2	NL Hydro Request	All available generation
PAB G10	28-Jan-13	4:22 PM	28-Jan-13	6:33 PM	2.7	NL Hydro Request	All available generation
Greenhill GT	28-Jan-13	4:12 PM	28-Jan-13	6:15 PM	16.2	NL Hydro Request	All available generation
Wesleyville GT	28-Jan-13	4:14 PM	28-Jan-13	6:37 PM	8.6	NL Hydro Request	All available generation
Mobile Diesel	29-Jan-13	8:07 AM	29-Jan-13	9:35 AM	2.3	NL Hydro Request	All available generation
PAB G10	29-Jan-13	7:38 AM	29-Jan-13	9:33 AM	2.6	NL Hydro Request	All available generation
Greenhill GT	29-Jan-13	7:20 AM	29-Jan-13	9:22 AM	16.5	NL Hydro Request	All available generation
Wesleyville GT	29-Jan-13	7:44 AM	29-Jan-13	9:36 AM	9.6	NL Hydro Request	All available generation
Mobile Diesel	8-Feb-13	7:27 AM	8-Feb-13	9:48 AM	2.4	NL Hydro Request	All available generation
PAB G10	8-Feb-13	8:06 AM	8-Feb-13	9:47 AM	2.6	NL Hydro Request	All available generation
Greenhill GT	8-Feb-13	7:31 AM	8-Feb-13	9:43 AM	15.9	NL Hydro Request	All available generation
Wesleyville GT	8-Feb-13	7:54 AM	8-Feb-13	8:17 AM	8.3	NL Hydro Request	All available generation
Wesleyville GT	8-Feb-13	2:19 PM	8-Feb-13	2:35 PM	4.0	NL Hydro Request	All available generation
Wesleyville GT	8-Feb-13	9:03 PM	8-Feb-13	10:59 PM	2.1	NL Hydro Request	All available generation
Mobile Diesel	9-Feb-13	11:02 AM	9-Feb-13	7:42 PM	2.3	NL Hydro Request	All available generation
Wesleyville GT	9-Feb-13	9:12 AM	9-Feb-13	9:21 AM	2.0	Testing	Repairs completed
PAB G10	9-Feb-13	10:35 AM	9-Feb-13	7:39 PM	2.7	NL Hydro Request	All available generation
Greenhill GT	9-Feb-13	10:12 AM	9-Feb-13	7:41 PM	17.7	NL Hydro Request	All available generation
Greenhill GT	10-Feb-13	11:28 AM	10-Feb-13	1:19 PM	14.9	NL Hydro Request	SUN 230kV Bus Lockout
Greenhill GT	12-Feb-13	2:24 PM	12-Feb-13	2:51 PM	15.7	Planned work	138kV TML Switching
Wesleyville GT	18-Feb-13	5:06 PM	18-Feb-13	5:53 PM	5.4	Testing	Monthly test run
Wesleyville GT	21-Feb-13	10:17 AM	21-Feb-13	11:04 AM	8.6	Testing	Turbine bearing inspection
Mobile GT	13-Mar-13	n/a	13-Mar-13	n/a	4.0	NL Hydro Request	Holyrood station service test
Greenhill GT	21-Mar-13	10:01 AM	21-Mar-13	10:34 AM	2.5	Testing	Monthly test run
PAB G10	26-Mar-13	2:02 PM	26-Mar-13	2:28 PM	1.1	Testing	Monthly test run
PAB G10	28-Mar-13	9:20 AM	28-Mar-13	12:30 PM	2.6	NL Hydro Request	Generation test
Greenhill GT	28-Mar-13	9:16 AM	28-Mar-13	12:41 PM	20.7	NL Hydro Request	Generation test
Wesleyville GT	28-Mar-13	9:45 AM	28-Mar-13	12:38 PM	9.6	NL Hydro Request	Generation test
Mobile Diesel	3-Apr-13	3:05 PM	3-Apr-13	3:22 PM	0.0	Testing	Phase rotation check
PAB G10	3-Apr-13	10:45 AM	3-Apr-13	11:00 AM	2.2	Testing	Monthly test run
Mobile GT	3-Apr-13	n/a	3-Apr-13	n/a	n/a	NL Hydro Request	Holyrood station service test

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Mobile GT	4-Apr-13	n/a	4-Apr-13	n/a	n/a	NL Hydro Request	Holyrood station service test
Wesleyville GT	16-Apr-13	1:44 PM	16-Apr-13	2:08 PM	4.2	Testing	Monthly test run
Wesleyville GT	17-Apr-13	7:52 AM	17-Apr-13	9:53 AM	8.3	NL Hydro Request	Loss of Supply from BDE
Greenhill GT	17-Apr-13	8:49 AM	17-Apr-13	10:02 AM	18.9	NL Hydro Request	Loss of Supply from BDE
Mobile Diesel	24-Apr-13	1:24 PM	24-Apr-13	1:48 PM	2.5	NL Hydro Request	At Holyrood
PAB G10	29-Apr-13	1:10 PM	29-Apr-13	2:10 PM	2.6	Testing	Monthly test run
Mobile Diesel	10-May-13	3:16 PM	10-May-13	3:41 PM	0.0	Testing	Black start test
Mobile GT	10-May-13	n/a	10-May-13	n/a	1.0	NL Hydro Request	Holyrood station service test
PAB G10	22-May-13	1:05 PM	22-May-13	2:05 PM	2.5	Testing	Monthly test run
Wesleyville GT	4-Jun-13	3:29 PM	4-Jun-13	3:57 PM	2.2	Testing	Repairs completed
Greenhill GT	10-Jun-13	11:44 AM	10-Jun-13	12:27 PM	2.5	Testing	Monthly test run
Mobile GT	25-Jun-13	1:30 PM	25-Jun-13	2:07 PM	4.0	Testing	Commission MGT at GBS
Mobile GT	26-Jun-13	8:15 AM	26-Jun-13	1:22 PM	2.8	NL Hydro Request	Outage on TL215
Mobile GT	28-Jun-13	10:49 AM	28-Jun-13	10:55 AM	2.7	Testing	Black start test
PAB G10	28-Jun-13	10:15 AM	28-Jun-13	11:15 AM	2.7	Testing	Monthly test run
Mobile Diesel	2-Jul-13	1:47 PM	2-Jul-13	5:35 PM	1.0	Planned work	Outage on 95L
Mobile Diesel	3-Jul-13	7:19 AM	3-Jul-13	4:30 PM	1.0	Planned work	Outage on 95L
Mobile Diesel	4-Jul-13	6:53 AM	4-Jul-13	4:22 PM	1.0	Planned work	Outage on 95L
Wesleyville GT	5-Jul-13	10:06 AM	5-Jul-13	11:02 AM	8.4	Testing	Monthly test run
Mobile Diesel	8-Jul-13	6:48 AM	8-Jul-13	5:06 PM	0.9	Planned work	Outage on 95L
Mobile Diesel	9-Jul-13	6:39 AM	9-Jul-13	4:14 PM	0.8	Planned work	Outage on 95L
Wesleyville GT	9-Jul-13	11:30 AM	9-Jul-13	12:13 PM	8.6	Testing	Repairs completed
Wesleyville GT	9-Jul-13	12:45 PM	9-Jul-13	1:59 PM	8.6	Testing	Repairs completed
Mobile Diesel	10-Jul-13	6:36 AM	10-Jul-13	4:54 PM	0.8	Planned work	Outage on 95L
Mobile Diesel	11-Jul-13	8:00 AM	11-Jul-13	3:59 PM	1.0	Planned work	Outage on 95L
Mobile Diesel	12-Jul-13	6:26 AM	12-Jul-13	5:39 PM	1.0	Planned work	Outage on 95L
Mobile Diesel	17-Jul-13	6:46 AM	17-Jul-13	2:25 PM	0.9	Planned work	Outage on 95L
Mobile Diesel	18-Jul-13	8:59 AM	18-Jul-13	1:39 PM	1.0	Planned work	Outage on 95L
Mobile GT	22-Jul-13	10:30 AM	22-Jul-13	11:16 AM	4.5	Testing	Ready for outage
Mobile Diesel	25-Jul-13	11:57 AM	25-Jul-13	12:15 PM	1.0	Testing	Commission MD3 at GBS
Mobile GT	29-Jul-13	7:50 AM	29-Jul-13	4:40 PM	3.5	NL Hydro Request	Outage on TL215

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Mobile GT	30-Jul-13	7:46 AM	30-Jul-13	5:09 PM	3.0	NL Hydro Request	Outage on TL215
Mobile GT	31-Jul-13	7:41 AM	31-Jul-13	4:36 PM	3.0	NL Hydro Request	Outage on TL215
Mobile GT	1-Aug-13	7:45 AM	1-Aug-13	4:17 PM	2.5	NL Hydro Request	Outage on TL215
Mobile GT	2-Aug-13	7:50 AM	2-Aug-13	1:31 PM	2.5	NL Hydro Request	Outage on TL215
Mobile Diesel	6-Aug-13	3:08 AM	6-Aug-13	5:33 AM	2.5	NL Hydro Request	Unplanned outage on TL215
Mobile Diesel	9-Aug-13	10:25 AM	9-Aug-13	2:17 PM	1.9	NL Hydro Request	Insulator repair on TL215
PAB G10	9-Aug-13	10:04 AM	9-Aug-13	2:10 PM	2.6	NL Hydro Request	Insulator repair on TL215
Mobile GT	14-Aug-13	6:01 PM	14-Aug-13	6:12 PM	n/a	Testing	Commission MGT at Bonavista
Mobile GT	15-Aug-13	12:51 PM	15-Aug-13	6:34 PM	n/a	Planned work	Outage on 123L
Mobile GT	29-Aug-13	9:13 AM	29-Aug-13	4:21 PM	n/a	Planned work	Outage on 123L
Greenhill GT	11-Sep-13	10:59 AM	11-Sep-13	11:30 AM	2.8	Testing	Monthly test run
Mobile Diesel	24-Sep-13	11:37 AM	24-Sep-13	12:32 PM	2.0	Testing	Monthly test run
PAB G10	25-Sep-13	1:03 PM	25-Sep-13	2:03 PM	2.4	Testing	Monthly test run
Wesleyville GT	25-Sep-13	4:10 PM	25-Sep-13	5:11 PM	6.0	Testing	Monthly test run
Wesleyville GT	26-Sep-13	9:49 AM	26-Sep-13	10:46 AM	0.2	Testing	Black start test
Wesleyville GT	16-Oct-13	9:34 AM	16-Oct-13	10:27 AM	6.2	Testing	Monthly test run
Greenhill GT	17-Oct-13	11:29 AM	17-Oct-13	12:23 PM	3.5	Testing	Black start test
PAB G10	23-Oct-13	11:51 AM	23-Oct-13	12:51 PM	2.0	Testing	Monthly test run
Mobile Diesel	28-Oct-13	10:42 AM	28-Oct-13	11:41 AM	2.2	Testing	Monthly test run
Mobile Diesel	22-Nov-13	11:00 PM	24-Nov-13	12:54 AM	1.2	Storm Repair	Badger Ice Storm
PAB G10	28-Nov-13	10:35 AM	28-Nov-13	11:35 AM	2.7	Testing	Monthly test run
Greenhill GT	5-Dec-13	11:58 AM	5-Dec-13	12:29 PM	2.5	Testing	Monthly test run
PAB G10	9-Dec-13	1:05 PM	9-Dec-13	2:05 PM	2.4	Testing	Monthly test run
Mobile Diesel	16-Dec-13	3:37 PM	16-Dec-13	4:18 PM	1.2	Storm Repair	Badger Ice Storm
PAB G10	26-Dec-13	4:43 PM	26-Dec-13	6:45 PM	3.2	NL Hydro Request	All available generation
Greenhill GT	26-Dec-13	4:51 PM	26-Dec-13	6:45 PM	15.7	NL Hydro Request	All available generation
Wesleyville GT	26-Dec-13	4:54 PM	26-Dec-13	6:24 PM	8.5	NL Hydro Request	All available generation
Mobile GT	28-Dec-13	n/a	28-Dec-13	n/a	n/a	NL Hydro Request	All available generation
PAB G10	29-Dec-13	4:42 PM	29-Dec-13	8:22 PM	2.6	NL Hydro Request	All available generation
Greenhill GT	29-Dec-13	4:35 PM	29-Dec-13	9:55 PM	16.0	NL Hydro Request	All available generation
Wesleyville GT	29-Dec-13	4:39 PM	29-Dec-13	5:17 PM	8.7	NL Hydro Request	All available generation

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Mobile GT	30-Dec-13	10:00 AM	30-Dec-13	5:56 PM	n/a	NL Hydro Request	All available generation
PAB G10	30-Dec-13	11:13 AM	30-Dec-13	6:57 PM	3.2	NL Hydro Request	All available generation
Greenhill GT	30-Dec-13	9:37 AM	30-Dec-13	6:56 PM	18.3	NL Hydro Request	All available generation
Wesleyville GT	30-Dec-13	9:43 AM	30-Dec-13	7:21 PM	10.0	NL Hydro Request	All available generation
Greenhill GT	31-Dec-13	8:35 AM	31-Dec-13	9:34 AM	2.5	Testing	Testing - operator training
Greenhill GT	31-Dec-13	5:03 PM	31-Dec-13	6:59 PM	10.8	NL Hydro Request	All available generation
Wesleyville GT	31-Dec-13	5:06 PM	31-Dec-13	5:54 PM	9.2	NL Hydro Request	All available generation
Greenhill GT	1-Jan-14	4:06 PM	1-Jan-14	9:42 PM	11.2	NL Hydro Request	All available generation
PAB G10	1-Jan-14	4:10 PM	1-Jan-14	9:14 PM	2.7	NL Hydro Request	All available generation
Mobile GT	1-Jan-14	4:15 PM	1-Jan-14	11:30 PM	7.0	NL Hydro Request	All available generation
Wesleyville GT	1-Jan-14	4:15 PM	1-Jan-14	6:27 PM	8.8	NL Hydro Request	All available generation
Mobile GT	2-Jan-14	6:50 AM	2-Jan-14	11:00 PM	6.5	NL Hydro Request	All available generation
PAB G10	2-Jan-14	3:00 PM	2-Jan-14	11:00 PM	2.7	NL Hydro Request	All available generation
PAB G10	2-Jan-14	6:36 AM	2-Jan-14	1:26 PM	2.7	NL Hydro Request	All available generation
Greenhill GT	2-Jan-14	7:38 AM	3-Jan-14	12:12 AM	20.8	NL Hydro Request	All available generation
Wesleyville GT	2-Jan-14	4:27 PM	2-Jan-14	4:55 PM	8.9	NL Hydro Request	All available generation
Wesleyville GT	2-Jan-14	5:24 PM	2-Jan-14	5:47 PM	6.3	NL Hydro Request	All available generation
Wesleyville GT	2-Jan-14	9:38 PM	2-Jan-14	9:59 PM	8.5	NL Hydro Request	All available generation
Mobile GT	3-Jan-14	4:00 PM	3-Jan-14	11:40 PM	6.5	NL Hydro Request	All available generation
PAB G10	3-Jan-14	6:38 AM	3-Jan-14	8:00 PM	2.7	NL Hydro Request	All available generation
Greenhill GT	3-Jan-14	6:31 AM	3-Jan-14	2:07 PM	17.0	NL Hydro Request	All available generation
Wesleyville GT	3-Jan-14	1:22 PM	3-Jan-14	9:36 PM	10.3	NL Hydro Request	All available generation
Greenhill GT	3-Jan-14	3:51 PM	3-Jan-14	7:00 PM	20.1	NL Hydro Request	All available generation
Mobile GT	4-Jan-14	4:50 PM	4-Jan-14	7:30 PM	6.0	NL Hydro Request	All available generation
Wesleyville GT	4-Jan-14	8:02 AM	4-Jan-14	8:05 AM	5.1	NL Hydro Request	All available generation
Wesleyville GT	4-Jan-14	8:22 AM	4-Jan-14	8:29 AM	5.1	NL Hydro Request	All available generation
Wesleyville GT	4-Jan-14	8:43 AM	4-Jan-14	9:05 AM	6.3	NL Hydro Request	All available generation
Wesleyville GT	4-Jan-14	11:27 AM	4-Jan-14	12:10 PM	7.1	NL Hydro Request	All available generation
Wesleyville GT	4-Jan-14	2:44 PM	4-Jan-14	3:33 PM	9.5	NL Hydro Request	All available generation
PAB G10	4-Jan-14	10:26 AM	5-Jan-14	11:50 AM	2.8	NL Hydro Request	All available generation
Greenhill GT	4-Jan-14	3:48 PM	4-Jan-14	7:14 PM	18.5	NL Hydro Request	All available generation

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Mobile GT	5-Jan-14	n/a	5-Jan-14	n/a	n/a	NL Hydro Request	All available generation
PAB G10	5-Jan-14	2:45 PM	5-Jan-14	3:25 PM	2.7	NL Hydro Request	All available generation
Greenhill GT	5-Jan-14	1:43 PM	5-Jan-14	9:27 PM	18.2	NL Hydro Request	All available generation
Greenhill GT	5-Jan-14	11:04 PM	6-Jan-14	12:38 PM	18.7	NL Hydro Request	All available generation
Mobile GT	6-Jan-14	n/a	6-Jan-14	n/a	n/a	NL Hydro Request	All available generation
Greenhill GT	6-Jan-14	4:11 PM	6-Jan-14	6:19 PM	15.7	NL Hydro Request	All available generation
Mobile GT	8-Jan-14	6:30 AM	8-Jan-14	7:10 PM	n/a	NL Hydro Request	All available generation
Greenhill GT	8-Jan-14	6:52 AM	8-Jan-14	7:36 PM	18.6	NL Hydro Request	All available generation
Mobile GT	10-Jan-14	4:25 PM	10-Jan-14	6:30 PM	n/a	NL Hydro Request	All available generation
Greenhill GT	10-Jan-14	6:29 AM	10-Jan-14	8:57 AM	16.5	NL Hydro Request	All available generation
Greenhill GT	10-Jan-14	4:38 PM	10-Jan-14	6:13 PM	15.7	NL Hydro Request	All available generation
Greenhill GT	19-Jan-14	12:27 AM	19-Jan-14	3:30 AM	15.9	NL Hydro Request	Maintenance on SUN B1
Wesleyville GT	23-Jan-14	10:28 AM	23-Jan-14	11:22 AM	5.0	Testing	Repairs completed
Mobile Diesel	28-Jan-14	1:00 PM	28-Jan-14	2:00 PM	2.0	Testing	Commission MD3 at GBS
Mobile GT	1-Feb-14	11:23 AM	1-Feb-14	11:45 AM	6.0	NL Hydro Request	All available generation
Mobile GT	4-Feb-14	8:50 AM	4-Feb-14	9:46 AM	6.0	NL Hydro Request	All available generation
Wesleyville GT	4-Feb-14	8:14 AM	4-Feb-14	9:43 AM	8.4	NL Hydro Request	All available generation
Greenhill GT	6-Feb-14	5:04 PM	6-Feb-14	8:58 PM	15.9	NL Hydro Request	All available generation
Greenhill GT	9-Feb-14	9:53 AM	9-Feb-14	10:05 AM	15.7	Testing	Ready for generation test
Mobile GT	9-Feb-14	10:20 AM	9-Feb-14	10:52 AM	6.0	Testing	Ready for generation test
Wesleyville GT	9-Feb-14	12:57 PM	9-Feb-14	2:02 PM	9.4	Testing	Ready for generation test
Greenhill GT	10-Feb-14	6:40 AM	10-Feb-14	9:52 AM	20.7	NL Hydro Request	Generation test
Wesleyville GT	10-Feb-14	6:41 AM	10-Feb-14	9:40 AM	9.6	NL Hydro Request	Generation test
Mobile GT	10-Feb-14	6:44 AM	10-Feb-14	9:52 AM	6.0	NL Hydro Request	Generation test
Greenhill GT	10-Feb-14	10:18 AM	10-Feb-14	1:07 PM	15.6	NL Hydro Request	All available generation
Wesleyville GT	10-Feb-14	3:44 PM	10-Feb-14	4:04 PM	2.0	Testing	AC Generator checks
Greenhill GT	10-Feb-14	4:36 PM	10-Feb-14	7:19 PM	15.6	NL Hydro Request	All available generation
Mobile GT	11-Feb-14	6:44 AM	11-Feb-14	9:30 AM	6.0	NL Hydro Request	All available generation
Greenhill GT	11-Feb-14	7:36 AM	11-Feb-14	8:52 AM	15.7	NL Hydro Request	All available generation
Wesleyville GT	11-Feb-14	10:33 AM	11-Feb-14	11:02 AM	2.1	Testing	AC Generator checks
Wesleyville GT	11-Feb-14	12:00 PM	11-Feb-14	12:23 PM	5.1	Testing	AC Generator checks

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Mobile GT	12-Feb-14	7:06 AM	12-Feb-14	9:22 AM	6.0	NL Hydro Request	All available generation
Greenhill GT	12-Feb-14	6:50 AM	12-Feb-14	9:18 AM	15.8	NL Hydro Request	All available generation
Wesleyville GT	12-Feb-14	6:54 AM	12-Feb-14	7:07 AM	7.4	NL Hydro Request	All available generation
Wesleyville GT	12-Feb-14	7:29 AM	12-Feb-14	9:26 AM	7.4	NL Hydro Request	All available generation
Mobile Diesel	27-Feb-14	5:18 PM	27-Feb-14	6:18 PM	2.0	Testing	Repairs completed
Mobile GT	4-Mar-14	6:37 AM	4-Mar-14	8:59 AM	6.0	NL Hydro Request	All available generation
Mobile GT	4-Mar-14	4:57 PM	5-Mar-14	10:30 PM	6.0	NL Hydro Request	All available generation
Greenhill GT	4-Mar-14	6:44 AM	4-Mar-14	8:55 AM	15.6	NL Hydro Request	All available generation
Mobile Diesel	4-Mar-14	6:45 AM	4-Mar-14	9:21 AM	2.1	NL Hydro Request	All available generation
Wesleyville GT	4-Mar-14	6:46 AM	4-Mar-14	8:57 AM	8.4	NL Hydro Request	All available generation
Greenhill GT	4-Mar-14	4:51 PM	4-Mar-14	10:21 PM	16.0	NL Hydro Request	All available generation
Mobile Diesel	4-Mar-14	4:56 PM	4-Mar-14	10:21 PM	2.0	NL Hydro Request	All available generation
Wesleyville GT	4-Mar-14	5:01 PM	4-Mar-14	10:20 PM	8.4	NL Hydro Request	All available generation
Mobile GT	5-Mar-14	5:58 AM	5-Mar-14	10:33 AM	6.0	NL Hydro Request	All available generation
Greenhill GT	5-Mar-14	5:59 AM	5-Mar-14	10:28 AM	16.6	NL Hydro Request	All available generation
Mobile Diesel	5-Mar-14	6:23 AM	5-Mar-14	10:24 AM	2.1	NL Hydro Request	All available generation
Wesleyville GT	5-Mar-14	6:24 AM	5-Mar-14	8:27 AM	8.4	NL Hydro Request	All available generation
Greenhill GT	5-Mar-14	6:34 PM	5-Mar-14	8:38 PM	15.8	NL Hydro Request	All available generation
Mobile Diesel	5-Mar-14	6:35 PM	5-Mar-14	8:50 PM	2.0	NL Hydro Request	All available generation
Mobile GT	5-Mar-14	6:45 PM	5-Mar-14	8:45 PM	6.0	NL Hydro Request	All available generation
Greenhill GT	6-Mar-14	6:15 AM	6-Mar-14	8:48 AM	16.5	NL Hydro Request	All available generation
Mobile Diesel	6-Mar-14	6:20 AM	6-Mar-14	8:45 AM	2.1	NL Hydro Request	All available generation
Mobile GT	6-Mar-14	8:48 AM	6-Mar-14	9:08 AM	6.0	NL Hydro Request	All available generation
Mobile GT	7-Mar-14	6:47 AM	7-Mar-14	9:25 AM	6.0	NL Hydro Request	All available generation
Mobile Diesel	7-Mar-14	6:46 AM	7-Mar-14	9:29 AM	2.1	NL Hydro Request	All available generation
Greenhill GT	7-Mar-14	6:47 AM	7-Mar-14	9:26 AM	15.9	NL Hydro Request	All available generation
Mobile GT	11-Mar-14	7:40 AM	11-Mar-14	9:25 AM	6.0	NL Hydro Request	All available generation
Mobile Diesel	11-Mar-14	7:31 AM	11-Mar-14	9:18 AM	2.1	NL Hydro Request	All available generation
Greenhill GT	11-Mar-14	8:07 AM	11-Mar-14	9:20 AM	16.4	NL Hydro Request	All available generation
Mobile GT	19-Mar-14	6:00 AM	19-Mar-14	8:50 AM	6.0	NL Hydro Request	All available generation
Greenhill GT	19-Mar-14	5:53 AM	19-Mar-14	8:22 AM	16.2	NL Hydro Request	All available generation

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Greenhill GT	19-Mar-14	10:11 AM	19-Mar-14	6:15 PM	15.5	NL Hydro Request	All available generation
Greenhill GT	20-Mar-14	10:00 AM	20-Mar-14	10:31 AM	3.5	Testing	Monthly test run
PAB G10	24-Apr-14	8:45 AM	24-Apr-14	1:00 PM	2.0	Testing	Monthly test run
Mobile Diesel	28-Apr-14	10:53 AM	28-Apr-14	11:51 AM	2.0	Testing	Monthly test run
Greenhill GT	13-May-14	1:44 PM	13-May-14	2:14 PM	3.6	Testing	Power Turbine Inspection
Greenhill GT	15-May-14	11:51 AM	15-May-14	12:51 PM	5.6	Testing	Black start test
PAB G10	22-May-14	1:07 PM	22-May-14	2:07 PM	2.3	Testing	Monthly test run
Mobile Diesel	29-May-14	2:21 PM	29-May-14	3:19 PM	2.0	Testing	Monthly test run
Mobile Diesel	26-Jun-14	1:14 PM	26-Jun-14	2:18 PM	2.0	Testing	Monthly test run
Greenhill GT	4-Jul-14	11:30 AM	4-Jul-14	12:29 PM	3.9	Testing	Black start test
PAB G10	7-Jul-14	1:21 PM	7-Jul-14	2:21 PM	2.3	Testing	Monthly test run
Greenhill GT	22-Jul-14	8:59 AM	22-Jul-14	9:20 AM	14.6	NL Hydro Request	Switching at SUN T4
Mobile GT	23-Jul-14	7:35 PM	23-Jul-14	7:55 PM	3.6	Testing	Commission MGT at GBS
PAB G10	28-Jul-14	11:55 AM	28-Jul-14	12:55 PM	2.4	Testing	Monthly test run
Mobile GT	29-Jul-14	11:30 AM	29-Jul-14	11:49 AM	5.0	Testing	Repairs completed
Mobile Diesel	30-Jul-14	10:30 AM	30-Jul-14	11:30 AM	2.0	Testing	Monthly test run
Mobile GT	11-Aug-14	10:57 AM	11-Aug-14	11:40 AM	1.0	Testing	Black start test
Mobile GT	13-Aug-14	10:55 AM	13-Aug-14	11:25 AM	4.0	Testing	In preparation of outage
Greenhill GT	13-Aug-14	1:52 PM	13-Aug-14	2:23 PM	18.7	Testing	Monthly test run
Greenhill GT	17-Aug-14	5:44 AM	17-Aug-14	8:42 AM	12.9	NL Hydro Request	Switching at SUN TL212
Greenhill GT	17-Aug-14	10:27 AM	17-Aug-14	2:02 PM	10.9	NL Hydro Request	Switching at SUN TL212
Mobile GT	18-Aug-14	7:36 AM	18-Aug-14	5:34 PM	5.0	NL Hydro Request	Outage on TL215
Mobile GT	20-Aug-14	8:30 AM	20-Aug-14	4:09 PM	3.0	NL Hydro Request	Outage on TL215
Mobile GT	21-Aug-14	7:53 AM	21-Aug-14	8:25 AM	2.7	NL Hydro Request	Outage on TL215
Mobile GT	22-Aug-14	7:44 AM	22-Aug-14	6:51 PM	3.1	NL Hydro Request	Outage on TL214
Mobile GT	23-Aug-14	7:43 AM	23-Aug-14	6:15 PM	3.0	NL Hydro Request	Outage on TL214
Mobile Diesel	28-Aug-14	9:37 AM	28-Aug-14	10:39 AM	1.8	Testing	Monthly test run
PAB G10	28-Aug-14	1:43 PM	28-Aug-14	2:43 PM	2.5	Testing	Monthly test run
Mobile GT	12-Sep-14	n/a	12-Sep-14	n/a	2.2	Testing	Online for 2 hours
PAB G10	29-Sep-14	9:30 AM	29-Sep-14	10:30 AM	2.5	Testing	Monthly test run
Mobile Diesel	29-Sep-14	11:36 AM	29-Sep-14	12:37 PM	2.1	Testing	Monthly test run

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Mobile GT	8-Oct-14	8:27 AM	8-Oct-14	2:44 PM	5.0	Planned work	Bell Island generation supply
Mobile Diesel	9-Oct-14	12:49 PM	9-Oct-14	3:29 PM	1.9	Testing	Monthly test run
Mobile Diesel	10-Oct-14	11:08 AM	10-Oct-14	2:00 PM	1.7	Testing	Repairs completed
Mobile Diesel	14-Oct-14	11:15 AM	14-Oct-14	3:11 PM	1.8	Testing	Repairs completed
Mobile GT	15-Oct-14	11:00 AM	15-Oct-14	6:03 PM	5.0	Planned Work	Bell Island generation supply
PAB G10	29-Oct-14	1:35 PM	29-Oct-14	2:30 PM	2.5	Testing	Monthly test run
Wesleyville GT	14-Nov-14	6:56 PM	14-Nov-14	7:35 PM	9.6	Testing	Gas generator overhaul
Wesleyville GT	15-Nov-14	8:34 AM	15-Nov-14	10:27 AM	10.2	Testing	Gas generator overhaul
Mobile Diesel	25-Nov-14	9:10 AM	25-Nov-14	9:38 AM	2.0	Testing	Repairs completed
PAB G10	25-Nov-14	9:00 AM	25-Nov-14	9:30 AM	2.4	Testing	Monthly test run
Mobile GT	25-Nov-14	3:47 PM	25-Nov-14	4:20 PM	3.0	Testing	Ready for generation test
Greenhill GT	26-Nov-14	1:29 PM	26-Nov-14	2:29 PM	3.6	Testing	Monthly test run
Wesleyville GT	27-Nov-14	9:45 AM	27-Nov-14	11:41 AM	10.4	Testing	Repairs completed
Mobile Diesel	27-Nov-14	9:49 AM	27-Nov-14	11:37 AM	2.0	NL Hydro Request	Generation test
PAB G10	27-Nov-14	9:45 AM	27-Nov-14	11:45 AM	2.5	NL Hydro Request	Generation test
Greenhill GT	27-Nov-14	9:50 AM	27-Nov-14	11:46 AM	20.6	NL Hydro Request	Generation test
Mobile GT	27-Nov-14	9:45 AM	27-Nov-14	11:40 AM	6.0	NL Hydro Request	Generation test
Greenhill GT	2-Dec-14	12:00 AM	2-Dec-14	1:56 AM	10.7	NL Hydro Request	Outage to SUN Bus B1
Wesleyville GT	2-Dec-14	12:03 AM	2-Dec-14	1:48 AM	8.3	NL Hydro Request	Outage to SUN Bus B1
Greenhill GT	10-Dec-14	4:22 PM	10-Dec-14	4:51 PM	3.8	Testing	Following fuel system repairs
Mobile Diesel	15-Dec-14	1:23 PM	15-Dec-14	2:23 PM	1.9	Testing	Monthly test run
Wesleyville GT	18-Dec-14	12:52 PM	18-Dec-14	1:34 PM	5.1	Testing	Repairs completed
Wesleyville GT	18-Dec-14	2:09 PM	18-Dec-14	2:27 PM	2.1	Testing	Repairs completed
Greenhill GT	18-Dec-14	2:30 PM	18-Dec-14	2:59 PM	3.8	Testing	Black start test
PAB G10	19-Dec-14	10:33 AM	19-Dec-14	11:33 AM	2.4	Testing	Monthly test run
Wesleyville GT	20-Dec-14	10:31 AM	20-Dec-14	11:37 AM	5.3	Testing	Repairs completed
Wesleyville GT	21-Dec-14	9:37 AM	21-Dec-14	10:16 AM	5.2	Testing	Repairs completed
Greenhill GT	3-Jan-15	4:48 PM	3-Jan-15	10:04 PM	6.4	NL Hydro Request	Minimum load requested
Wesleyville GT	3-Jan-15	5:15 PM	3-Jan-15	9:45 PM	4.4	NL Hydro Request	Minimum load requested
Wesleyville GT	4-Jan-15	5:27 PM	4-Jan-15	6:40 PM	7.4	NL Hydro Request	Minimum load requested
Greenhill GT	4-Jan-15	5:48 PM	4-Jan-15	6:39 PM	5.5	NL Hydro Request	Minimum load requested

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Wesleyville GT	6-Jan-15	4:11 PM	6-Jan-15	6:34 PM	7.3	NL Hydro Request	All available generation
Greenhill GT	6-Jan-15	4:12 PM	6-Jan-15	6:36 PM	16.0	NL Hydro Request	All available generation
Wesleyville GT	14-Jan-15	5:14 PM	14-Jan-15	5:30 PM	2.0	NL Hydro Request	All available generation
Mobile GT	19-Jan-15	1:56 PM	19-Jan-15	2:48 PM	3.2	Testing	Repairs completed
Greenhill GT	22-Jan-15	9:32 AM	22-Jan-15	11:57 AM	10.1	NL Hydro Request	Holyrood GT testing
Greenhill GT	23-Jan-15	10:01 AM	23-Jan-15	12:48 PM	5.6	NL Hydro Request	Holyrood GT testing
PAB G10	27-Jan-15	1:00 PM	27-Jan-15	2:00 PM	2.5	Testing	Monthly test run
Greenhill GT	27-Jan-15	4:20 PM	27-Jan-15	6:22 PM	5.8	NL Hydro Request	Holyrood GT testing
Mobile Diesel	28-Jan-15	8:55 AM	28-Jan-15	9:52 AM	2.0	Testing	Monthly test run
Greenhill GT	29-Jan-15	9:47 AM	29-Jan-15	10:25 AM	5.7	NL Hydro Request	Holyrood GT testing
Greenhill GT	5-Feb-15	11:19 AM	5-Feb-15	4:21 PM	5.9	NL Hydro Request	Holyrood GT testing
Greenhill GT	9-Feb-15	9:07 AM	9-Feb-15	9:28 AM	10.6	NL Hydro Request	All available generation
Mobile Diesel	23-Feb-15	1:59 PM	23-Feb-15	2:57 PM	2.0	Testing	Monthly test run
PAB G10	25-Feb-15	12:43 PM	25-Feb-15	1:41 PM	2.4	Testing	Monthly test run
Greenhill GT	2-Mar-15	2:21 PM	2-Mar-15	3:21 PM	0.3	Testing	Black start test
PAB G10	4-Mar-15	8:07 AM	4-Mar-15	10:47 AM	2.4	NL Hydro Request	Holyrood G3 Tripped
Greenhill GT	4-Mar-15	7:46 AM	4-Mar-15	7:58 AM	17.2	NL Hydro Request	Holyrood G3 Tripped
Mobile Diesel	4-Mar-15	7:53 AM	4-Mar-15	10:48 AM	2.1	NL Hydro Request	Holyrood G3 Tripped
Wesleyville GT	4-Mar-15	9:10 AM	4-Mar-15	12:15 PM	11.3	NL Hydro Request	Holyrood G3 Tripped
Greenhill GT	5-Mar-15	8:49 AM	5-Mar-15	9:47 AM	2.6	Testing	Check voltage regulation
Greenhill GT	5-Mar-15	1:42 PM	5-Mar-15	1:51 PM	2.5	Testing	Check voltage regulation
Mobile GT	11-Mar-15	10:22 AM	11-Mar-15	11:30 AM	3.0	Testing	Engine/Turbine inspection
Mobile GT	13-Mar-15	7:01 AM	13-Mar-15	9:12 AM	6.0	NL Hydro Request	All available generation
Greenhill GT	13-Mar-15	6:14 AM	13-Mar-15	10:30 AM	19.0	NL Hydro Request	All available generation
Wesleyville GT	13-Mar-15	6:18 AM	13-Mar-15	9:35 AM	7.7	NL Hydro Request	All available generation
Mobile GT	23-Apr-15	3:00 PM	23-Apr-15	3:30 PM	2.4	Testing	Work on 94L and 95L at TRP
PAB G10	24-Apr-15	10:16 AM	24-Apr-15	11:15 AM	2.5	Testing	Monthly test run
Mobile Diesel	27-Apr-15	1:49 PM	27-Apr-15	2:47 PM	2.0	Testing	Monthly test run
Mobile GT	4-May-15	6:36 AM	4-May-15	4:22 PM	n/a	Planned work	Work on 94L and 95L at TRP
Mobile GT	5-May-15	10:18 AM	5-May-15	6:49 PM	n/a	Planned work	Work on 94L and 95L at TRP
Mobile GT	6-May-15	6:49 AM	6-May-15	4:40 PM	n/a	Planned work	Work on 94L and 95L at TRP

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Mobile GT	7-May-15	6:50 AM	7-May-15	4:38 PM	n/a	Planned work	Work on 94L and 95L at TRP
Mobile GT	8-May-15	6:48 AM	8-May-15	2:52 PM	n/a	Planned work	Work on 94L and 95L at TRP
Mobile GT	11-May-15	6:56 AM	11-May-15	4:16 PM	n/a	Planned work	Work on 94L and 95L at TRP
Mobile GT	12-May-15	6:42 AM	12-May-15	4:36 PM	n/a	Planned work	Work on 94L and 95L at TRP
Mobile GT	13-May-15	7:38 AM	13-May-15	5:16 PM	n/a	Planned work	Work on 94L and 95L at TRP
Mobile GT	14-May-15	6:53 AM	14-May-15	4:43 PM	n/a	Planned work	Work on 94L and 95L at TRP
Greenhill GT	14-May-15	12:58 PM	14-May-15	1:57 PM	15.9	Testing	Monthly test run
Mobile GT	15-May-15	6:40 AM	15-May-15	3:24 PM	n/a	Planned work	Work on 94L and 95L at TRP
Mobile GT	19-May-15	6:39 AM	19-May-15	5:57 PM	n/a	Planned work	Work on 94L and 95L at TRP
PAB G10	19-May-15	1:10 PM	19-May-15	2:10 PM	2.4	Testing	Monthly test run
Mobile Diesel	19-May-15	1:06 PM	19-May-15	2:06 PM	2.1	Testing	Monthly test run
Mobile GT	20-May-15	9:03 AM	20-May-15	3:27 PM	n/a	Planned work	Work on 94L and 95L at TRP
Mobile GT	29-May-15	3:40 PM	29-May-15	4:10 PM	2.9	Testing	At ABC for work on 410L
Mobile GT	1-Jun-15	11:50 AM	1-Jun-15	6:30 PM	n/a	Planned work	At ABC for work on 410L
Mobile GT	2-Jun-15	7:54 AM	2-Jun-15	8:20 PM	n/a	Planned work	At ABC for work on 410L
Mobile GT	3-Jun-15	7:53 AM	3-Jun-15	8:14 PM	n/a	Planned work	At ABC for work on 410L
Mobile GT	4-Jun-15	8:00 AM	4-Jun-15	7:07 PM	n/a	Planned work	At ABC for work on 410L
Mobile GT	5-Jun-15	2:50 PM	5-Jun-15	3:50 PM	3.0	Testing	Repairs completed
Mobile GT	6-Jun-15	7:58 AM	6-Jun-15	8:09 PM	n/a	Planned work	At ABC for work on 410L
Mobile GT	7-Jun-15	7:57 AM	7-Jun-15	8:11 PM	n/a	Planned work	At ABC for work on 410L
Mobile GT	8-Jun-15	7:39 AM	8-Jun-15	2:52 PM	n/a	Planned work	At ABC for work on 410L
Wesleyville GT	10-Jun-15	2:25 PM	10-Jun-15	3:06 PM	2.5	Testing	Repairs completed
Wesleyville GT	10-Jun-15	4:46 PM	10-Jun-15	4:49 PM	1.9	Testing	Repairs completed
Mobile GT	11-Jun-15	11:07 AM	11-Jun-15	11:07 AM	n/a	Planned work	At ABC for work on 410L
Wesleyville GT	11-Jun-15	1:30 PM	11-Jun-15	2:16 PM	3.1	Testing	Repairs completed
Mobile GT	13-Jun-15	12:45 PM	13-Jun-15	6:00 PM	2.2	Testing	Repairs completed
Mobile GT	15-Jun-15	7:35 AM	15-Jun-15	8:14 PM	n/a	Planned work	At ABC for work on 410L
Mobile GT	16-Jun-15	7:45 AM	16-Jun-15	8:09 PM	n/a	Planned work	At ABC for work on 410L
Mobile GT	17-Jun-15	7:55 AM	17-Jun-15	8:11 PM	n/a	Planned work	At ABC for work on 410L
Mobile GT	18-Jun-15	8:49 AM	18-Jun-15	8:13 PM	n/a	Planned work	At ABC for work on 410L
Mobile GT	19-Jun-15	7:41 AM	19-Jun-15	8:09 PM	n/a	Planned work	At ABC for work on 410L

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Mobile GT	20-Jun-15	8:24 AM	20-Jun-15	10:14 AM	2.0	Testing	Packing up at ABC
Mobile GT	23-Jun-15	8:50 AM	23-Jun-15	10:33 AM	2.0	Testing	Packing up at ABC
Wesleyville GT	25-Jun-15	2:50 PM	25-Jun-15	3:42 PM	2.2	Testing	Repairs completed
Greenhill GT	29-Jun-15	2:08 PM	29-Jun-15	3:02 PM	1.2	Testing	Black start test
PAB G10	30-Jun-15	10:27 AM	30-Jun-15	11:27 AM	2.5	Testing	Monthly test run
Mobile GT	1-Jul-15	3:31 PM	1-Jul-15	3:50 PM	2.0	Testing	At LEW for feeder rebuild
Mobile Diesel	2-Jul-15	8:39 AM	2-Jul-15	9:37 AM	2.0	Testing	Monthly test run
Mobile GT	2-Jul-15	4:00 PM	2-Jul-15	4:18 PM	5.0	Planned work	At LEW for feeder rebuild
Mobile GT	5-Jul-15	7:17 AM	5-Jul-15	11:10 AM	n/a	Planned work	At LEW for feeder rebuild
Mobile GT	6-Jul-15	1:10 PM	6-Jul-15	1:48 PM	1.4	Testing	Packing up at LEW
Mobile GT	9-Jul-15	4:00 PM	9-Jul-15	4:30 PM	n/a	Testing	Commissioning at TWG
Wesleyville GT	9-Jul-15	10:27 AM	9-Jul-15	11:07 AM	3.3	Testing	Repairs completed
Mobile GT	10-Jul-15	12:27 PM	10-Jul-15	12:43 PM	n/a	Testing	Commissioning at TWG
Mobile GT	14-Jul-15	8:53 AM	14-Jul-15	4:59 PM	4.0	Planned work	At TWG, work on 114L/140L
Mobile GT	15-Jul-15	5:17 AM	15-Jul-15	4:22 PM	n/a	Planned work	At TWG, work on 114L/140L
Mobile GT	22-Jul-15	6:15 AM	22-Jul-15	1:18 PM	3.0	Planned Work	At TWG, work on 114L/140L
Wesleyville GT	22-Jul-15	12:59 PM	22-Jul-15	2:55 PM	2.4	Testing	Monthly test run
PAB G10	22-Jul-15	12:40 PM	22-Jul-15	1:40 PM	2.2	Testing	Monthly test run
Mobile Diesel	23-Jul-15	1:15 PM	23-Jul-15	2:15 PM	1.9	Testing	Monthly test run
Mobile GT	4-Aug-15	6:17 AM	4-Aug-15	5:49 PM	n/a	Planned work	At TWG for work on 140L
Mobile GT	5-Aug-15	5:57 AM	5-Aug-15	2:45 PM	n/a	Planned work	At TWG for work on 140L
Greenhill GT	11-Aug-15	1:51 PM	11-Aug-15	3:06 PM	5.6	NL Hydro Request	Maintenance at SUN
Mobile Diesel	24-Aug-15	12:59 PM	24-Aug-15	1:58 PM	2.0	Testing	Monthly test run
Mobile GT	2-Sep-15	6:34 AM	2-Sep-15	2:46 PM	3.0	Planned work	At TWG for work on 140L
PAB G10	8-Sep-15	1:45 PM	8-Sep-15	2:01 PM	2.7	Testing	Repairs completed
PAB G10	9-Sep-15	9:26 AM	9-Sep-15	9:36 AM	0.0	Testing	Repairs completed
Greenhill GT	10-Sep-15	11:48 AM	10-Sep-15	1:03 PM	18.6	Testing	Monthly test run
Mobile GT	13-Sep-15	5:51 AM	13-Sep-15	n/a	n/a	Planned work	At TWG for work on 140L
Greenhill GT	14-Sep-15	9:46 AM	14-Sep-15	2:18 PM	9.0	NL Hydro Request	Maintenance at SUN
Mobile GT	21-Sep-15	11:06 AM	21-Sep-15	2:58 PM	n/a	Testing	Commission MGT at GBS
Mobile GT	22-Sep-15	4:58 PM	22-Sep-15	6:50 PM	n/a	Testing	Monthly test run

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Mobile GT	25-Sep-15	1:59 PM	25-Sep-15	2:24 PM	n/a	Testing	Ready for outage
Greenhill GT	27-Sep-15	7:02 AM	27-Sep-15	3:49 PM	3.0	NL Hydro Request	Stage 2 Alert
Mobile GT	28-Sep-15	7:58 AM	28-Sep-15	3:51 PM	n/a	NL Hydro Request	Outage on TL215
Mobile GT	29-Sep-15	12:00 PM	29-Sep-15	6:16 PM	n/a	NL Hydro Request	Outage on TL215
PAB G10	30-Sep-15	1:29 PM	30-Sep-15	2:29 PM	2.6	Testing	Monthly test run
Greenhill GT	30-Sep-15	7:56 AM	30-Sep-15	2:49 PM	11.1	NL Hydro Request	Maintenance at SUN
Mobile Diesel	5-Oct-15	7:20 AM	5-Oct-15	9:55 AM	2.5	NL Hydro Request	Outage on TL214
Mobile GT	5-Oct-15	7:01 AM	5-Oct-15	9:55 AM	n/a	NL Hydro Request	Outage on TL214
Mobile Diesel	7-Oct-15	3:18 PM	7-Oct-15	3:42 PM	1.6	Testing	Monthly test run
PAB G10	14-Oct-15	5:08 PM	14-Oct-15	5:22 PM	1.0	Testing	Preparation for outage
Mobile GT	14-Oct-15	1:13 PM	14-Oct-15	1:31 PM	2.5	Testing	Monthly test run
Mobile Diesel	15-Oct-15	6:38 AM	15-Oct-15	2:59 PM	1.4	NL Hydro Request	Outage on TL215
PAB G10	15-Oct-15	6:13 AM	15-Oct-15	3:08 PM	1.6	NL Hydro Request	Outage on TL215
Greenhill GT	15-Oct-15	12:59 PM	15-Oct-15	1:57 PM	0.2	Testing	Black start test
Mobile GT	15-Oct-15	5:53 AM	15-Oct-15	3:54 PM	2.0	NL Hydro Request	Outage on TL214
Greenhill GT	22-Oct-15	3:26 PM	22-Oct-15	4:30 PM	18.6	Testing	Synchronous Condenser Test
Greenhill GT	26-Oct-15	2:48 PM	26-Oct-15	3:11 PM	2.5	Testing	Synchronous Condenser Test
Greenhill GT	27-Oct-15	12:58 PM	27-Oct-15	1:25 PM	19.5	Testing	Load transfer SPO T4 to T5
PAB G10	23-Nov-15	1:30 PM	23-Nov-15	2:27 PM	2.2	Testing	Monthly test run
Mobile Diesel	27-Nov-15	1:04 PM	27-Nov-15	2:06 PM	1.9	Testing	Monthly test run
Mobile Diesel	10-Dec-15	10:51 AM	10-Dec-15	11:41 AM	2.0	Testing	Monthly test run
Wesleyville GT	10-Dec-15	11:46 AM	10-Dec-15	2:01 PM	10.4	Testing	Repairs completed
PAB G10	12-Dec-15	3:00 PM	12-Dec-15	3:30 PM	2.5	Testing	Preparation for outage
Mobile Diesel	13-Dec-15	2:24 AM	13-Dec-15	5:03 AM	1.9	NL Hydro Request	Outage on TL215
PAB G10	13-Dec-15	2:13 AM	13-Dec-15	5:07 AM	2.5	NL Hydro Request	Outage on TL215
Mobile GT	14-Dec-15	n/a	14-Dec-15	n/a	n/a	Testing	Ready for generation test
Greenhill GT	15-Dec-15	1:04 PM	15-Dec-15	2:04 PM	11.0	Testing	Ready for generation test
PAB G10	15-Dec-15	1:34 PM	15-Dec-15	2:20 PM	1.8	Testing	Ready for generation test
Mobile GT	16-Dec-15	9:50 AM	16-Dec-15	12:50 PM	6.0	NL Hydro Request	Generation test
PAB G10	16-Dec-15	9:37 AM	16-Dec-15	12:52 PM	2.7	NL Hydro Request	Generation test
Greenhill GT	16-Dec-15	9:48 AM	16-Dec-15	12:53 PM	20.6	NL Hydro Request	Generation test

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Mobile Diesel	16-Dec-15	9:56 AM	16-Dec-15	12:50 PM	2.2	NL Hydro Request	Generation Test
Wesleyville GT	16-Dec-15	10:09 AM	16-Dec-15	10:30 AM	8.4	Testing	Ready for generation test
Wesleyville GT	16-Dec-15	10:47 AM	16-Dec-15	12:47 PM	6.9	NL Hydro Request	Generation test
Mobile GT	6-Jan-16	7:21 AM	6-Jan-16	8:58 AM	n/a	NL Hydro Request	All available generation
Mobile GT	6-Jan-16	4:14 PM	6-Jan-16	6:25 PM	n/a	NL Hydro Request	All available generation
Greenhill GT	6-Jan-16	6:52 AM	6-Jan-16	9:50 AM	18.9	NL Hydro Request	All available generation
Greenhill GT	6-Jan-16	3:57 PM	6-Jan-16	8:16 PM	19.0	NL Hydro Request	All available generation
Greenhill GT	8-Jan-16	6:57 AM	8-Jan-16	9:36 AM	18.7	NL Hydro Request	All available generation
Mobile GT	8-Jan-16	7:06 AM	8-Jan-16	9:34 AM	6.0	NL Hydro Request	All available generation
Greenhill GT	8-Jan-16	3:00 PM	8-Jan-16	8:33 PM	18.7	NL Hydro Request	All available generation
Mobile GT	8-Jan-16	3:15 PM	8-Jan-16	6:59 PM	6.0	NL Hydro Request	All available generation
Greenhill GT	9-Jan-16	4:01 PM	9-Jan-16	6:56 PM	18.6	NL Hydro Request	All available generation
Mobile GT	9-Jan-16	4:05 PM	9-Jan-16	6:13 PM	6.0	NL Hydro Request	All available generation
Mobile GT	13-Jan-16	4:08 PM	13-Jan-16	6:09 PM	6.0	NL Hydro Request	All available generation
Greenhill GT	13-Jan-16	3:56 PM	13-Jan-16	6:13 PM	19.1	NL Hydro Request	All available generation
Mobile GT	21-Jan-16	6:20 AM	21-Jan-16	9:30 AM	6.0	NL Hydro Request	All available generation
Greenhill GT	21-Jan-16	11:28 AM	21-Jan-16	12:30 PM	21.0	NL Hydro Request	All available generation
Mobile Diesel	23-Jan-16	2:44 PM	23-Jan-16	3:46 PM	1.9	Testing	Repairs completed
Greenhill GT	26-Jan-16	6:35 AM	26-Jan-16	9:45 AM	18.8	NL Hydro Request	All available generation
Mobile GT	26-Jan-16	7:03 AM	26-Jan-16	9:00 AM	6.0	NL Hydro Request	All available generation
PAB G10	29-Jan-16	9:13 AM	29-Jan-16	9:45 AM	1.1	Testing	Monthly test run
Mobile GT	3-Feb-16	3:42 PM	3-Feb-16	7:22 PM	6.0	NL Hydro Request	All available generation
Greenhill GT	3-Feb-16	5:01 AM	3-Feb-16	10:04 AM	18.8	NL Hydro Request	All available generation
Mobile GT	3-Feb-16	7:39 AM	3-Feb-16	9:40 AM	6.0	NL Hydro Request	All available generation
Greenhill GT	3-Feb-16	3:36 PM	3-Feb-16	8:35 PM	18.8	NL Hydro Request	All available generation
Mobile GT	4-Feb-16	6:24 AM	4-Feb-16	8:22 AM	6.0	NL Hydro Request	All available generation
Greenhill GT	4-Feb-16	7:13 AM	4-Feb-16	8:29 AM	18.8	NL Hydro Request	All available generation
Mobile GT	8-Feb-16	6:16 AM	8-Feb-16	8:46 AM	6.0	NL Hydro Request	All available generation
Mobile GT	8-Feb-16	3:30 PM	8-Feb-16	7:09 PM	6.0	NL Hydro Request	All available generation
Greenhill GT	8-Feb-16	6:17 AM	8-Feb-16	9:18 AM	18.9	NL Hydro Request	All available generation
Greenhill GT	8-Feb-16	4:05 PM	8-Feb-16	7:47 PM	18.8	NL Hydro Request	All available generation

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Greenhill GT	9-Feb-16	1:44 PM	9-Feb-16	3:40 PM	20.7	NL Hydro Request	All available generation
Mobile Diesel	11-Feb-16	11:29 AM	11-Feb-16	12:29 PM	2.0	Testing	Monthly test run
Greenhill GT	14-Feb-16	3:29 PM	14-Feb-16	7:06 PM	18.2	NL Hydro Request	All available generation
Mobile GT	14-Feb-16	5:05 PM	14-Feb-16	7:06 PM	6.0	NL Hydro Request	All available generation
Greenhill GT	15-Feb-16	6:02 AM	15-Feb-16	9:35 AM	18.0	NL Hydro Request	All available generation
Mobile GT	15-Feb-16	6:36 AM	15-Feb-16	9:46 AM	6.0	NL Hydro Request	All available generation
Mobile GT	15-Feb-16	3:21 PM	15-Feb-16	9:18 PM	6.0	NL Hydro Request	All available generation
Greenhill GT	15-Feb-16	3:33 PM	15-Feb-16	9:57 PM	18.4	NL Hydro Request	All available generation
Greenhill GT	16-Feb-16	6:21 AM	16-Feb-16	8:52 AM	18.0	NL Hydro Request	All available generation
Mobile GT	16-Feb-16	6:25 AM	16-Feb-16	9:32 AM	6.0	NL Hydro Request	All available generation
Mobile GT	19-Feb-16	5:26 PM	19-Feb-16	6:11 PM	6.0	NL Hydro Request	All available generation
Greenhill GT	20-Feb-16	11:26 AM	20-Feb-16	12:28 PM	18.6	Testing	Monthly test run
Mobile GT	24-Feb-16	6:33 AM	24-Feb-16	10:03 AM	6.0	NL Hydro Request	All available generation
Mobile GT	24-Feb-16	5:03 PM	24-Feb-16	8:58 PM	6.0	NL Hydro Request	All available generation
Mobile GT	25-Feb-16	7:16 AM	25-Feb-16	8:46 AM	6.0	NL Hydro Request	All available generation
Greenhill GT	27-Feb-16	5:28 PM	27-Feb-16	6:24 PM	18.0	Testing	Repairs completed
PAB G10	29-Feb-16	10:02 AM	29-Feb-16	10:41 AM	1.4	Testing	Monthly test run
Wesleyville GT	29-Feb-16	12:03 PM	29-Feb-16	12:07 PM	2.7	Testing	Lube Oil Cooler Inspection
Wesleyville GT	29-Feb-16	12:46 PM	29-Feb-16	1:43 PM	4.5	Testing	Lube Oil Cooler Inspection
Wesleyville GT	29-Feb-16	2:38 PM	29-Feb-16	3:15 PM	4.6	Testing	Lube Oil Cooler Inspection
Wesleyville GT	29-Feb-16	4:23 PM	29-Feb-16	4:49 PM	4.4	Testing	Lube Oil Cooler Inspection
Wesleyville GT	1-Mar-16	10:34 AM	1-Mar-16	12:22 PM	4.5	Testing	Lube Oil Cooler Inspection
Mobile GT	9-Mar-16	5:56 AM	9-Mar-16	8:25 AM	6.0	NL Hydro Request	All available generation
Greenhill GT	9-Mar-16	5:56 AM	9-Mar-16	7:17 AM	18.7	NL Hydro Request	All available generation
Mobile Diesel	11-Mar-16	10:18 AM	11-Mar-16	11:21 AM	1.7	Testing	Monthly test run
Greenhill GT	17-Mar-16	11:28 AM	17-Mar-16	12:27 PM	0.9	Testing	Black start test
Mobile GT	25-Mar-16	6:29 AM	25-Mar-16	8:32 AM	6.0	NL Hydro Request	Avalon generation
Greenhill GT	31-Mar-16	10:30 AM	31-Mar-16	11:32 AM	20.7	Testing	Monthly test run
PAB G10	11-Apr-16	2:01 PM	11-Apr-16	3:01 PM	2.2	Testing	Monthly test run
Mobile Diesel	29-Apr-16	1:00 PM	29-Apr-16	1:59 PM	1.7	Testing	Monthly test run
Greenhill GT	4-May-16	3:23 PM	4-May-16	4:21 PM	5.8	Testing	Monthly test run

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Mobile Diesel	26-May-16	2:21 PM	26-May-16	3:19 PM	1.5	Testing	Monthly test run
PAB G10	31-May-16	12:42 PM	31-May-16	1:42 PM	2.5	Testing	Monthly test run
Mobile Diesel	15-Jun-16	1:44 PM	15-Jun-16	2:45 PM	1.7	Testing	Monthly test run
Mobile GT	7-Jul-16	10:39 AM	7-Jul-16	11:40 AM	3.4	Testing	Monthly test run
Mobile Diesel	7-Jul-16	2:21 PM	7-Jul-16	2:52 PM	1.8	Testing	Monthly test run
Mobile Diesel	18-Jul-16	1:56 PM	18-Jul-16	2:31 PM	1.8	Testing	Repairs completed
PAB G10	20-Jul-16	10:27 AM	20-Jul-16	11:27 AM	2.4	Testing	Monthly test run
Mobile Diesel	9-Aug-16	12:22 PM	9-Aug-16	1:05 PM	1.5	Testing	Commission MD3 at GIL
Mobile Diesel	15-Aug-16	6:28 AM	15-Aug-16	7:03 PM	1.2	Planned work	At GIL for work on 358L
Mobile Diesel	16-Aug-16	7:52 AM	16-Aug-16	6:20 PM	1.1	Planned work	At GIL for work on 358L
Mobile Diesel	17-Aug-16	6:26 PM	17-Aug-16	7:02 PM	0.0	Testing	Repairs completed
Mobile Diesel	18-Aug-16	6:31 AM	18-Aug-16	6:34 PM	1.1	Planned work	At GIL for work on 358L
Mobile Diesel	25-Aug-16	7:39 PM	25-Aug-16	8:12 PM	0.0	Testing	Repairs completed
Mobile Diesel	26-Aug-16	1:00 PM	26-Aug-16	4:46 PM	n/a	Planned work	At GIL for work on 358L
PAB G10	29-Aug-16	1:07 PM	29-Aug-16	2:12 PM	2.5	Testing	Monthly test run
Mobile Diesel	15-Sep-16	8:36 AM	15-Sep-16	6:15 PM	1.7	Testing	Monthly test run
Mobile Diesel	27-Sep-16	11:27 AM	27-Sep-16	3:31 PM	1.5	Testing	Commission MD3 at GBS
Mobile GT	28-Sep-16	11:53 AM	28-Sep-16	12:38 PM	3.0	Testing	Ready for outage
PAB G10	28-Sep-16	10:39 AM	28-Sep-16	11:40 AM	2.7	Testing	Ready for outage
Mobile GT	29-Sep-16	7:00 AM	29-Sep-16	4:24 PM	n/a	NL Hydro Request	Outage on TL215
PAB G10	29-Sep-16	6:30 AM	29-Sep-16	4:30 PM	2.4	NL Hydro Request	Outage on TL215
Mobile GT	30-Sep-16	6:30 AM	30-Sep-16	12:15 PM	n/a	NL Hydro Request	Outage on TL214
PAB G10	30-Sep-16	6:23 AM	30-Sep-16	12:03 PM	1.5	NL Hydro Request	Outage on TL214
Mobile GT	14-Oct-16	3:59 PM	14-Oct-16	4:49 PM	n/a	Testing	Ready for outage
Mobile GT	16-Oct-16	12:58 AM	16-Oct-16	5:23 AM	n/a	Planned work	At PUL for work on 59L
Greenhill GT	18-Oct-16	9:54 AM	18-Oct-16	11:43 AM	20.7	Testing	Gas generator overhaul
Mobile Diesel	21-Oct-16	11:05 AM	21-Oct-16	11:40 AM	1.8	Testing	Monthly test run
Greenhill GT	24-Oct-16	3:52 PM	24-Oct-16	4:05 PM	20.0	Testing	Gas generator overhaul
PAB G10	31-Oct-16	2:28 PM	31-Oct-16	3:08 PM	2.6	Testing	Monthly test run
Mobile GT	19-Nov-16	n/a	19-Nov-16	n/a	n/a	Testing	Ready for outage
Mobile GT	20-Nov-16	12:16 AM	20-Nov-16	2:45 AM	n/a	Planned work	At PUL for work on 59L

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Greenhill GT	22-Nov-16	12:29 AM	22-Nov-16	1:56 AM	16.6	Testing	Monthly test run
Wesleyville GT	24-Nov-16	12:44 PM	24-Nov-16	2:22 PM	8.6	Testing	Post repair test run
PAB G10	28-Nov-16	10:27 AM	28-Nov-16	11:27 AM	2.2	Testing	Monthly test run
Wesleyville GT	1-Dec-16	10:17 AM	1-Dec-16	5:35 PM	8.6	Testing	Post repair test run
PAB G10	13-Dec-16	2:12 PM	13-Dec-16	2:48 PM	2.6	Testing	Repairs completed
Mobile GT	13-Dec-16	4:25 PM	13-Dec-16	5:15 PM	4.0	Testing	Test run at Whitbourne
Mobile Diesel	13-Dec-16	4:47 PM	13-Dec-16	5:17 PM	2.0	Testing	Monthly test run
Mobile Diesel	15-Dec-16	10:02 AM	15-Dec-16	12:32 PM	2.3	Testing	Repairs completed
PAB G10	15-Dec-16	9:42 AM	15-Dec-16	12:28 PM	2.6	Testing	Ready for planned outage
Greenhill GT	15-Dec-16	10:34 AM	15-Dec-16	12:19 PM	21.2	Testing	Monthly test run
Wesleyville GT	15-Dec-16	10:21 AM	15-Dec-16	12:28 PM	9.2	Testing	Ready for planned outage
Mobile Diesel	16-Dec-16	7:27 AM	16-Dec-16	2:42 PM	1.6	NL Hydro Request	Outage on TL215
PAB G10	16-Dec-16	7:52 AM	16-Dec-16	4:21 PM	2.3	NL Hydro Request	Outage on TL215
Greenhill GT	17-Dec-16	10:41 AM	17-Dec-16	11:51 AM	20.6	Testing	Repairs completed
Wesleyville GT	18-Dec-16	7:08 AM	18-Dec-16	2:48 PM	8.3	Planned work	116L Repairs
Greenhill GT	5-Jan-17	2:03 PM	5-Jan-17	3:06 PM	20.8	Testing	Monthly test run
Mobile GT	10-Jan-17	4:28 PM	10-Jan-17	5:28 PM	2.8	Testing	Commission MGT at GBS
Wesleyville GT	14-Jan-17	9:01 AM	14-Jan-17	10:34 AM	8.5	Testing	Turbine bearing inspection
Wesleyville GT	16-Jan-17	1:49 PM	16-Jan-17	3:54 PM	8.4	Testing	Ready for generation test
Wesleyville GT	17-Jan-17	8:09 AM	17-Jan-17	10:04 AM	8.6	Testing	Ready for generation test
Greenhill GT	19-Jan-17	1:12 PM	19-Jan-17	2:12 PM	0.5	Testing	Black start test
Mobile GT	23-Jan-17	4:20 PM	23-Jan-17	6:05 PM	3.8	NL Hydro Request	All available generation
PAB G10	23-Jan-17	10:44 AM	23-Jan-17	11:16 AM	1.8	Testing	Ready for generation test
Mobile GT	24-Jan-17	4:42 PM	24-Jan-17	9:30 PM	2.2	NL Hydro Request	Outage on TL215
Wesleyville GT	24-Jan-17	9:57 AM	24-Jan-17	12:01 PM	8.8	Testing	Ready for generation test
Mobile GT	24-Jan-17	1:29 PM	24-Jan-17	2:44 PM	1.9	Testing	Ready for generation test
Greenhill GT	24-Jan-17	12:20 PM	24-Jan-17	12:51 PM	20.6	Testing	Ready for generation test
PAB G10	24-Jan-17	5:30 PM	24-Jan-17	9:30 PM	2.4	NL Hydro Request	Outage on TL215
Greenhill GT	24-Jan-17	3:03 PM	24-Jan-17	4:02 PM	21.0	Testing	Ready for generation test
Greenhill GT	25-Jan-17	9:38 AM	25-Jan-17	11:54 AM	20.6	NL Hydro Request	Generation test
PAB G10	25-Jan-17	9:53 AM	25-Jan-17	11:50 AM	2.5	NL Hydro Request	Generation test

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Mobile GT	25-Jan-17	9:41 AM	25-Jan-17	11:51 AM	5.6	NL Hydro Request	Generation test
Wesleyville GT	25-Jan-17	9:49 AM	25-Jan-17	11:56 AM	8.4	NL Hydro Request	Generation test
Greenhill GT	6-Feb-17	4:28 PM	6-Feb-17	6:28 PM	20.7	NL Hydro Request	All available generation
Greenhill GT	7-Feb-17	7:15 AM	7-Feb-17	8:48 AM	20.6	NL Hydro Request	All available generation
Greenhill GT	7-Feb-17	3:57 PM	7-Feb-17	10:07 PM	21.1	NL Hydro Request	All available generation
Wesleyville GT	7-Feb-17	4:02 PM	7-Feb-17	8:15 PM	8.6	NL Hydro Request	All available generation
Wesleyville GT	8-Feb-17	5:46 AM	8-Feb-17	12:04 PM	8.4	NL Hydro Request	All available generation
Greenhill GT	8-Feb-17	5:53 AM	8-Feb-17	11:41 AM	20.6	NL Hydro Request	All available generation
Greenhill GT	8-Feb-17	3:59 PM	8-Feb-17	7:02 PM	21.0	NL Hydro Request	All available generation
Wesleyville GT	8-Feb-17	4:22 PM	8-Feb-17	6:27 PM	8.1	NL Hydro Request	All available generation
Wesleyville GT	14-Feb-17	11:29 AM	14-Feb-17	2:57 PM	6.4	NL Hydro Request	All available generation
Wesleyville GT	14-Feb-17	4:35 PM	14-Feb-17	5:59 PM	8.5	NL Hydro Request	All available generation
PAB G10	17-Feb-17	2:17 PM	17-Feb-17	3:17 PM	2.0	Testing	Monthly test run
Greenhill GT	19-Feb-17	4:52 PM	19-Feb-17	5:00 PM	20.6	Testing	Black Start test
Greenhill GT	20-Feb-17	11:10 AM	20-Feb-17	12:06 PM	20.8	Testing	Repairs completed
Wesleyville GT	21-Feb-17	2:17 PM	21-Feb-17	2:50 PM	8.5	Testing	Repairs completed
Mobile GT	27-Feb-17	1:48 PM	27-Feb-17	2:30 PM	0.0	Testing	Black start test
Greenhill GT	28-Feb-17	4:26 PM	28-Feb-17	4:55 PM	4.5	Testing	Monthly test run
Mobile Diesel	2-Mar-17	3:23 PM	2-Mar-17	4:11 PM	1.6	Testing	Monthly test run
Greenhill GT	3-Mar-17	11:26 AM	3-Mar-17	12:26 PM	0.2	Testing	Repairs completed
Greenhill GT	12-Mar-17	10:07 AM	12-Mar-17	9:55 PM	22.1	NL Hydro Request	Carrying local load
Mobile Diesel	13-Mar-17	11:42 AM	13-Mar-17	12:59 PM	n/a	Testing	Commission MD3 at TRP
Mobile Diesel	13-Mar-17	3:15 PM	14-Mar-17	2:36 PM	n/a	Planned work	Outage on 95L
PAB G10	17-Mar-17	1:18 PM	17-Mar-17	2:20 PM	2.3	Testing	Monthly test run
Greenhill GT	21-Mar-17	2:01 PM	21-Mar-17	3:01 PM	20.7	Testing	Monthly test run
Greenhill GT	27-Mar-17	8:02 AM	27-Mar-17	9:05 AM	20.6	NL Hydro Request	All available generation
Mobile GT	29-Mar-17	2:12 PM	29-Mar-17	3:13 PM	n/a	Testing	Monthly test run
Wesleyville GT	30-Mar-17	11:30 AM	30-Mar-17	1:02 PM	6.5	Testing	Monthly test run
Greenhill GT	21-Apr-17	11:49 AM	21-Apr-17	12:50 PM	1.1	Testing	Black start test
Mobile GT	24-Apr-17	1:47 PM	24-Apr-17	3:26 PM	n/a	Testing	Monthly test run
Greenhill GT	2-May-17	6:40 AM	2-May-17	8:34 AM	10.6	NL Hydro Request	All available generation

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
PAB G10	15-May-17	9:16 AM	15-May-17	10:16 AM	2.3	Testing	Monthly test run
Wesleyville GT	18-May-17	10:27 AM	18-May-17	11:22 AM	8.2	Testing	Post repair test run
Mobile GT	25-May-17	1:53 PM	25-May-17	2:56 PM	n/a	Testing	Monthly test run
Greenhill GT	31-May-17	11:08 AM	31-May-17	12:10 PM	20.8	Testing	Monthly test run
PAB G10	12-Jun-17	10:21 AM	12-Jun-17	11:21 AM	2.4	Testing	Monthly test run
Mobile Diesel	12-Jun-17	3:25 PM	12-Jun-17	6:12 PM	2.3	Testing	Commission MD3 at RBK
Mobile Diesel	13-Jun-17	6:06 AM	13-Jun-17	6:39 PM	n/a	Planned work	Distribution outage RBK-01
Mobile Diesel	14-Jun-17	7:55 AM	14-Jun-17	10:23 AM	n/a	Planned work	Distribution outage RBK-01
Mobile Diesel	14-Jun-17	12:48 PM	14-Jun-17	4:51 PM	n/a	Planned work	Distribution outage RBK-01
Greenhill GT	14-Jun-17	12:33 PM	14-Jun-17	1:02 PM	12.1	Planned work	Load transfer SPO T4 to T5
Mobile Diesel	15-Jun-17	6:08 AM	15-Jun-17	7:00 PM	n/a	Planned work	Distribution outage RBK-01
Mobile Diesel	20-Jun-17	6:06 AM	20-Jun-17	11:42 AM	n/a	Planned work	Distribution outage RBK-01
Mobile Diesel	20-Jun-17	12:50 PM	20-Jun-17	3:53 PM	n/a	Planned work	Distribution outage RBK-01
Mobile Diesel	21-Jun-17	6:06 AM	21-Jun-17	11:08 AM	n/a	Planned work	Distribution outage RBK-01
Mobile Diesel	21-Jun-17	12:47 PM	21-Jun-17	4:39 PM	n/a	Planned work	Distribution outage RBK-01
Mobile Diesel	22-Jun-17	6:11 AM	22-Jun-17	11:00 AM	n/a	Planned work	Distribution outage RBK-01
Mobile Diesel	22-Jun-17	6:11 AM	22-Jun-17	11:00 AM	n/a	Planned work	Distribution outage RBK-01
Wesleyville GT	22-Jun-17	9:19 AM	22-Jun-17	10:22 AM	8.6	Testing	Monthly test run
Mobile Diesel	23-Jun-17	7:43 AM	23-Jun-17	11:43 AM	n/a	Planned work	Distribution outage RBK-01
Mobile Diesel	4-Jul-17	11:38 AM	4-Jul-17	2:43 PM	1.3	Testing	Commission MD3 at GBS
Greenhill GT	7-Jul-17	10:34 AM	7-Jul-17	11:34 AM	0.2	Testing	Black start test
Mobile GT	12-Jul-17	10:03 AM	12-Jul-17	11:03 AM	3.0	Testing	Monthly test run
PAB G10	12-Jul-17	1:30 PM	12-Jul-17	2:01 PM	1.0	Testing	Monthly test run
Mobile GT	17-Jul-17	6:19 AM	17-Jul-17	7:57 PM	4.0	NL Hydro Request	Outage on TL215
PAB G10	17-Jul-17	10:30 AM	17-Jul-17	7:10 PM	1.3	NL Hydro Request	Outage on TL215
Mobile GT	18-Jul-17	7:37 AM	18-Jul-17	5:20 PM	3.4	NL Hydro Request	Outage on TL215
Wesleyville GT	22-Jul-17	4:05 PM	22-Jul-17	6:50 PM	5.9	Unplanned Outage	115L and 116L Tripped
Wesleyville GT	15-Aug-17	9:31 AM	15-Aug-17	3:56 PM	2.2	Testing	Inspection and maintenance
Wesleyville GT	16-Aug-17	11:16 AM	16-Aug-17	5:30 PM	8.6	Testing	Inspection and maintenance
Mobile Diesel	21-Aug-17	1:11 PM	21-Aug-17	1:38 PM	n/a	Testing	Commission MD3 at ROB
Greenhill GT	23-Aug-17	9:48 AM	23-Aug-17	10:51 AM	19.9	Testing	Monthly test run

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Mobile Diesel	24-Aug-17	6:35 AM	24-Aug-17	n/a	n/a	Planned work	Distribution outage ROB-02
Wesleyville GT	24-Aug-17	6:48 PM	24-Aug-17	7:19 PM	9.0	Testing	Inspection and maintenance
PAB G10	5-Sep-17	9:31 AM	5-Sep-17	10:31 AM	2.6	Testing	Monthly test run
Wesleyville GT	7-Sep-17	10:05 AM	7-Sep-17	11:08 AM	6.4	Testing	Monthly test run
Mobile Diesel	18-Sep-17	3:16 PM	18-Sep-17	3:30 PM	1.9	Testing	Commission MD3 at GBS
Mobile GT	20-Sep-17	1:32 PM	20-Sep-17	1:52 PM	2.7	Testing	Repairs completed
PAB G10	25-Sep-17	11:02 AM	25-Sep-17	11:09 AM	0.1	Testing	Vibration Test
Mobile Diesel	27-Sep-17	2:46 PM	27-Sep-17	3:31 PM	1.5	Testing	Monthly test run
Mobile GT	28-Sep-17	11:36 AM	28-Sep-17	12:36 PM	3.2	Testing	Monthly test run
Wesleyville GT	3-Oct-17	5:53 AM	3-Oct-17	6:56 PM	5.3	Planned work	115L and 116L Repairs
Wesleyville GT	4-Oct-17	5:51 AM	4-Oct-17	6:28 PM	5.2	Planned work	115L and 116L Repairs
Wesleyville GT	5-Oct-17	5:50 AM	5-Oct-17	6:51 PM	5.8	Planned work	115L and 116L Repairs
Wesleyville GT	6-Oct-17	5:53 AM	6-Oct-17	6:42 PM	5.7	Planned work	115L and 116L Repairs
Greenhill GT	6-Oct-17	12:15 PM	6-Oct-17	1:16 PM	20.7	Testing	Monthly test run
Wesleyville GT	7-Oct-17	5:52 AM	7-Oct-17	6:15 PM	5.4	Planned work	115L and 116L Repairs
Wesleyville GT	8-Oct-17	5:52 AM	8-Oct-17	6:18 PM	5.7	Planned work	115L and 116L Repairs
Wesleyville GT	9-Oct-17	5:53 AM	9-Oct-17	6:19 PM	5.6	Planned work	115L and 116L Repairs
Mobile GT	30-Oct-17	1:36 PM	30-Oct-17	2:23 PM	3.0	Testing	Monthly test run
Mobile Diesel	30-Oct-17	10:42 AM	30-Oct-17	11:31 AM	1.6	Testing	Monthly test run
Greenhill GT	31-Oct-17	12:43 PM	31-Oct-17	1:43 PM	1.0	Testing	Black start test
Greenhill GT	1-Nov-17	11:30 AM	1-Nov-17	12:08 PM	3.8	Testing	Monthly test run
Wesleyville GT	2-Nov-17	10:36 AM	2-Nov-17	11:20 AM	5.8	Testing	Infra-red scanning
Mobile GT	22-Nov-17	9:29 AM	22-Nov-17	10:36 AM	2.4	Testing	Monthly test run
Mobile Diesel	22-Nov-17	1:00 PM	22-Nov-17	2:06 PM	1.6	Testing	Monthly test run
Greenhill GT	23-Nov-17	11:03 AM	23-Nov-17	12:03 PM	21.4	Testing	Monthly test run
PAB G10	28-Nov-17	1:48 PM	28-Nov-17	2:48 PM	2.0	Testing	Monthly test run
Wesleyville GT	30-Nov-17	11:33 AM	30-Nov-17	12:10 PM	9.0	Testing	Vibration test
Greenhill GT	5-Dec-17	2:38 PM	5-Dec-17	2:54 PM	5.6	Testing	Repairs completed
Wesleyville GT	7-Dec-17	10:03 AM	7-Dec-17	10:20 AM	2.5	Testing	Fuel meter calibration
Greenhill GT	12-Dec-17	5:42 AM	12-Dec-17	6:50 AM	16.1	Planned work	Load transfer SPO T4 to T5
PAB G10	12-Dec-17	9:13 AM	12-Dec-17	9:29 AM	0.3	Testing	Ready for generation test

Requests for Information

Unit	Date of Dispatch	Time of Dispatch	Date of Recall	Time of Recall	Amount Dispatched (MW)	Reason for Dispatch	Remarks
Mobile GT	12-Dec-17	9:56 AM	12-Dec-17	10:23 AM	2.0	Testing	Ready for generation test
Mobile Diesel	12-Dec-17	10:19 AM	12-Dec-17	10:37 AM	1.6	Testing	Ready for generation test
Wesleyville GT	12-Dec-17	11:56 AM	12-Dec-17	12:47 PM	8.5	Testing	Ready for generation test
PAB G10	13-Dec-17	10:04 AM	13-Dec-17	11:45 AM	2.0	NL Hydro Request	Generation test
Greenhill GT	13-Dec-17	10:05 AM	13-Dec-17	11:39 AM	20.6	NL Hydro Request	Generation test
Mobile GT	13-Dec-17	10:08 AM	13-Dec-17	11:42 AM	5.2	NL Hydro Request	Generation test
Mobile Diesel	13-Dec-17	10:08 AM	13-Dec-17	11:42 AM	1.8	NL Hydro Request	Generation test
Wesleyville GT	13-Dec-17	10:10 AM	13-Dec-17	11:39 AM	8.6	NL Hydro Request	Generation test
Greenhill GT	14-Dec-17	12:33 PM	14-Dec-17	1:32 PM	1.5	Testing	Black start test
Wesleyville GT	27-Dec-17	3:16 PM	27-Dec-17	10:42 PM	7.7	NL Hydro Request	All available generation
Mobile GT	27-Dec-17	4:30 PM	27-Dec-17	9:40 PM	4.7	NL Hydro Request	All available generation
Greenhill GT	27-Dec-17	3:30 PM	27-Dec-17	10:44 PM	22.7	NL Hydro Request	All available generation
Wesleyville GT	28-Dec-17	7:22 AM	28-Dec-17	12:08 PM	7.3	NL Hydro Request	All available generation
Greenhill GT	28-Dec-17	8:01 AM	28-Dec-17	12:06 PM	20.6	NL Hydro Request	All available generation