

1 Q. **Reference: Holyrood Gas Turbine - Combustor Inspection**

2

3 Why is Hydro proposing to undertaking planning and procurement for this project in 2020 to
4 complete the work and overhaul work in 2021 if it is Nalcor's plan to close Holyrood?

5

6

7 A. While Newfoundland and Labrador Hydro ("Hydro") currently plans to retire the Holyrood
8 Thermal Generating Station, it does not plan to retire the Holyrood Gas Turbine. It is anticipated
9 that the Holyrood Gas Turbine has a remaining useful service life of approximately 30 years.
10 Please refer to Hydro's response to CA-NLH-004 for further discussion of the service life of the
11 Holyrood Gas Turbine.

12

13 Hydro's maintenance strategy for the Holyrood Gas Turbine includes activities such as the
14 proposed combustor inspection and overhaul to ensure its reliable operation over its expected
15 service life.