

1 Q. Reference: Volume I, 2020 Capital Projects Over \$200,000 and less than \$500,000, Install
2 Recloser Remote Control (2020-2021) – Hampden and Upper Salmon, page D-23, lines 16 to
3 18, and pages D-31 to D-32

4
5 Appendix A provides a description of the factors and the methodology for how
6 the reclosers were prioritized. The top ten reclosers from the 2018 analysis are
7 proposed to be automated between 2019 and 2024.
8

9 Please provide a table showing the scoring for each of the 6 factors for the 10 highest priority
10 reclosers identified in Appendix A, Table A-7.

11
12 A. Table 1 provides the scoring for each of the 6 factors for the 10 highest priority reclosers
13 identified in Appendix A, Table A-7.

Table 1: Recloser Detail Prioritization Factors

Recloser	Customer Score	Accessibility Score	Location Score	Major Customer Score	ECC ¹ Rotation Score	SAIDI Score	Total Score ²
RH2-R1	3	1	5	3	3	3	405
HA1-R1	3	3	5	3	3	1	405
B1L1	1	11	5	5	1	1	275
CA1-R1	1	11	5	5	1	1	275
JA2-R1	3	3	5	1	3	2	270
JA1-R1	3	3	5	1	3	2	270
BU4-R1	3	5	3	1	1	5	225
FH1-R3	7	1	3	3	1	3	189
RH1-R1	5	1	5	1	3	2	150
MB1-R2	3	5	5	1	1	2	150

¹ Energy Control Centre (“ECC”).

² Total Score is the product of the individual scores.