

1 Q. **Reference: Volume II, Distribution System Upgrades (2020 – 2021) – Various, Tab 10, page 3,**
2 **Table 1**

3

4 What is the average number of customers on Hydro’s distribution feeders? In the response,
5 please provide the number of customers on the St. Anthony L3 feeder and indicate whether it is
6 greater or less than Hydro’s corporate average.

7

8

9 A. The average number of customers on Newfoundland and Labrador Hydro’s (“Hydro”)
10 distribution feeders is approximately 268.

11

12 The number of customers on the St. Anthony L3 feeder is approximately 786 and it is
13 significantly greater than Hydro’s corporate average.