

1 Q. Reference: Tab D; Volume I: Capital Projects Over \$200,000 and Less Than \$500,000 (Upgrade
2 Fuel Storage Tanks)

3

4 Hydro states on page D-10, lines 23-25:

5

6 In 2011, the 1998 vintage tank failed its internal inspection. As road delivery of
7 fuel to the remaining tank would ensure adequate fuel supply for the generating
8 plant, Hydro did not invest in repair of the failed tank and removed it from
9 service.

10

11 Was the 1998 storage tank cleaned and removed from the site of the Charlottetown Diesel Plant
12 when it was removed from service in 2011?

13

14

15 A. Yes. In accordance with the *Storage and Handling of Gasoline and Associated Products*
16 *Regulations*, 2003, NLR 58/03¹ the tank was cleaned, demolished, and removed from site after it
17 was removed from service.

¹ *Storage and Handling of Gasoline and Associated Products Regulations*, 2003, NLR 58/03 under the *Environmental Protection Act*, SNL 2002, c E-14.2.