

- 1 **Q. Please provide maintenance schedules describing all maintenance carried out on**  
 2 **each of the transmission lines which were the subject of the Technical Conference,**  
 3 **together with the cost of this maintenance for the past ten (10) years.**  
 4
- 5 A. Newfoundland Power's transmission lines are inspected annually. Details on the  
 6 inspection practices are outlined in *Newfoundland Power's Transmission Inspection and*  
 7 *Maintenance Practices*. A copy of these practices is provided as Attachment B in  
 8 response to Request for Information NLH-NP-001.  
 9
- 10 Maintenance costs for the 10 year period 2009 to 2018 for transmission lines 363L, 403L  
 11 and 49L are included in Table 1 below.

**Table 1**  
**Transmission Line**  
**Maintenance Costs - 2009 to 2018**

363L	\$1,334,129
403L	\$198,040
49L	\$51,254

- 12 The maintenance carried out on these transmission lines consisted of replacing  
 13 deteriorated poles, replacing damaged insulators, replacing deteriorated cross arms,  
 14 replacing damaged hardware and brush clearing.