

1 **Q. Reference: “2020 Capital Budget Application,” Newfoundland Power, July 5, 2019,**  
2 **Report 4.1 “Distribution Reliability Initiative,” sec. 3.1, at p. 2, Table 1**

**Table 1**  
**Distribution Interruption Statistics**  
**5-Year Average to December 31, 2018**

<b>Feeder</b>	<b>Customers</b>	<b>SAIFI</b>	<b>SAIDI</b>	<b>CHIKM</b>	<b>CIKM</b>
DUN-01	1,049	4.90	9.54	62	32
GBY-03	762	3.35	6.94	49	24
GDL-04	1,472	1.27	2.23	222	127
<b>Company Average</b>	-	<b>1.37</b>	<b>1.82</b>	<b>55</b>	<b>45</b>

3 **Using the five-year average presented in Table 1 and the data composition used to**  
4 **produce this data, how many and what percentage of Newfoundland Power feeders**  
5 **perform worse than CEA Region 2 for SAIDI?**  
6

7 A. As indicated in response to Request for Information NLH-NP-030, the components  
8 included in annual CEA data are not consistent with the composition of the data included  
9 in Table 1 referenced above. Newfoundland Power is therefore unable to provide the  
10 requested comparison to CEA Region 2 for SAIDI.