

1 **Q. Reference: “2020 Capital Budget Application,” Newfoundland Power, July 5, 2019,**
 2 **Report 4.2 “Feeder Additions for Load Growth.” secs. 2.1 and 2.3.**
 3

4 **On page 1, Newfoundland Power states “An overloaded section of conductor on a**
 5 **distribution line is at risk of failure. Failures are caused by overheating of the**
 6 **conductor as the customer load exceeds the conductor’s capacity ratings.”**
 7

8 **On page 3, footnote 4, Newfoundland Power states “Newfoundland Power’s**
 9 **planning criteria for maximum current on a single-phase distribution line is 85**
 10 **amps.”**
 11

12 **Please provide details of Newfoundland Power’s distribution planning criteria for**
 13 **maximum current on single-phase, two-phase, and three-phase lines and how the**
 14 **criteria were developed. How long has the 85 amp criteria been in effect for single-**
 15 **phase lines?**
 16

17 **A.** Newfoundland Power’s distribution planning criteria, including the 85 amp criteria, is
 18 longstanding and aligns with the *Distribution Planner’s Manual* published by the
 19 Canadian Electricity Association (“CEA”).¹
 20

21 The planning criteria for maximum current on a conductor under normal operating
 22 conditions is generally related to thermal loading and the adequacy of protection. The
 23 lower of these 2 constraints is used to set the maximum current.
 24

25 The planning criteria for maximum current on single-phase and 2-phase distribution lines
 26 is established to ensure safe and reliable operation of feeder protection devices. The 85
 27 amp limit assists Newfoundland Power in maintaining a balanced 3-phase system, which
 28 is necessary to detect line to ground faults. This, in turn, ensures adequate protection of
 29 the public, employees and electrical equipment in the event of a fault.²
 30

31 The planning criteria for maximum current on 3-phase lines is established based on the
 32 thermal loading constraints on the distribution conductor. The thermal loading
 33 constraints of a conductor relate to the potential failure of conductor caused by
 34 overheating resulting from excessive current flow. The planning ampacity is derived as a
 35 function of winter loading on the line, cold load pick-up and the sectionalizing capability
 36 of the line.
 37

38 Newfoundland Power’s planning criteria was reviewed by the Board’s consultant, The
 39 Liberty Consulting Group (“Liberty”), in 2014.³

¹ For example, the 2008 version of Newfoundland Power’s *Feeder Protection Overcurrent Setting Guidelines* included the 85 amp criteria for limiting current on distribution feeder taps.

² Line to ground faults can be difficult to detect as a consequence of low short circuit fault currents. To provide adequate protection a utility must set its line to ground protection setting as low as reasonably possible.

³ Regarding Newfoundland Power’s distribution and transmission planning, Liberty stated: “*Newfoundland Power employs appropriate criteria and standards*” (see the *Report on Island Interconnected System to Interconnection with Muskrat Falls addressing Newfoundland Power*, December 17, 2014, page 23).