

1 Q. Please provide a breakdown of the costs of a centralized diesel generating station in Port Hope
2 Simpson?

3

4

5 A. The cost of the centralized diesel generating station excluding the distribution costs for each
6 community is estimated at \$49 million. A breakdown of these costs has been detailed in Table 1.

**Table 1: Regional Diesel Plant Cost Breakdown
(\$ Millions)**

Component	Cost
Material, Equipment and Contract	36.0
Labour/Engineering/Other Direct Costs	4.7
Interest and Escalation/Contingency	8.3
Total	49.0

7 The distribution costs have been broken out as a part of Newfoundland and Labrador Hydro's
8 response to PUB-NLH-055 of this proceeding.