

1 Q. **Reference: Project - Upgrade Waste Water Equalization System - Holyrood**

2 How frequently are Hydro or other personnel required to enter the facility such as to be  
3 exposed to the mold? If there is a log of such entries please provide a complete copy of same,  
4 from at least 2014 (when Hydro states this project was first contemplated).

5

6

7 A. Newfoundland and Labrador Hydro and other personnel are required to enter the building for  
8 three main reasons: (i) cleaning, (ii) sampling, and (iii) adjusting the pH level in the basins as  
9 required. There is no log of such entries. On average, workers enter the building once per week  
10 for sampling and pH adjustments. Cleaning of the basin(s) typically occurs annually and workers  
11 follow a safe work method that lists the PPE<sup>1</sup> required, including half face respirators, for  
12 completing the work.

---

<sup>1</sup> Personal Protective Equipment (“PPE”).