

1 Q. Table 2 on page 11 of Schedule 1: Evidence of the Application shows Holyrood TGS Retirement
2 would reduce the available capacity by 490 MW, Hardwoods and Stephenville gas turbine
3 retirements 50 MW each.

4 Please confirm that Hydro uses 490 MW for Holyrood and 50 MW for each gas turbines for
5 capacity planning purposes.

6

7

8 A. It is confirmed.