

1 Q. Please describe the remediation work Hydro is performing to protect the sensitive electrical
2 equipment housed in the diesel station until the summer of 2023 when the new roof is
3 scheduled to be installed.

4

5

6 A. Newfoundland and Labrador Hydro is mitigating the risk of further leaks by covering control
7 panels and pull stations with plastic sheeting to redirect the water away from sensitive
8 equipment. Plant operators closely monitor the situation during heavy rain events and make
9 adjustments as required.