

1 Q. **Reference: Application**

2 Please provide a detailed calculation of the cost to own and operate Hydro’s small hydro
3 facilities (with capacity less than 1 MW), and the amount of money recovered annually from
4 customers attributable to Hydro’s small hydro generation facilities.

5
6

7 A. Newfoundland and Labrador Hydro (“Hydro”) operates three mini-hydro plants at Snook’s Arm,
8 Venams Bight, and Roddickton.¹ Table 1 contains the revenue requirement included in the 2019
9 Test Year and currently reflected in customer rates.

Table 1: 2019 Test Year Revenue Requirement – Small Hydro Facilities (\$000)

Revenue Requirement	2019 Test Year
Operating ²	92
Depreciation	93
Return on Rate Base ³	168
	<hr/> 353 <hr/>

¹ Mini-hydro facilities have a power range capacity between 0.1–1.0 MW. Small-hydro facilities have a power range capacity between 1.0–10.0 MW.
² Certain costs like supervision and planning are not tracked by facility and are not included.
³ Average net book value (\$3,086) x 2019 Test Year approved weighted average cost of capital (5.4%).