

1 **Q. (Reference NLH-NP-008, line 8) Why does Newfoundland Power not test a portion of**
2 **poles removed to build a condition assessment database as is Hydro's practice?**
3

4 A. Newfoundland Power's *Transmission Inspection and Maintenance Practices* outline the
5 inspection and testing procedures used to determine the integrity of transmission line
6 wood poles. The inspection and testing procedures include:
7

- 8 (i) Completing a visual inspection of the condition of the pole from the ground line
9 to the top on all quadrants;
10 (ii) Completing a sounding test, which involves striking a pole with a hammer at
11 regular intervals on all quadrants from the ground line to 2 metres above grade;
12 and
13 (iii) Performing core sampling by using an approved device to drill through the
14 centerline of the pole to extract a core sample for evaluation.
15

16 These testing procedures allow experienced Transmission and Distribution Planners to
17 obtain the required information about the condition of poles, including an indication of
18 the residual strength of a pole. For further information on the criteria used by
19 Newfoundland Power for decisions on the replacement of wood poles see response to
20 Request for Information NLH-NP-009.
21

22 It is Newfoundland Power's position that it would be prudent to await the results of the
23 second cycle of Hydro's test and treat program, which is scheduled for completion in
24 2023, before incurring any additional cost associated with testing removed poles. If the
25 results of Hydro's program indicate that the testing of a portion of poles is consistent with
26 Newfoundland Power's obligation to provide safe, least-cost, reliable service to
27 customers, the Company will review its practices to determine whether changes are
28 necessary.¹ The Board has indicated it is satisfied with this approach.²

¹ See response to Request for Information NLH-NP-008, lines 32-34.

² See response to Request for Information NLH-NP-008, lines 16-30.