

- 1 **Q. Reference: “2022/2023 General Rate Application,” Newfoundland Power, May 27,**
2 **2021, Volume 2, Section 3**
3
4 **Please provide a revised forecast assuming use of a ten-year historic load factor.**
5
6 **A. Table 1 provides the requested data.**

**Table 1:
Demand Forecast (10-Year Load Factor)¹
2021 to 2023 Pro Forma**

Year	Native Peak² (MW)
2021PF	1,343.9
2022PF	1,343.4
2023PF	1,334.5

¹ *Pro forma* native peak is based on an average of 10-year historical (normalized) load factors with 2020 excluded. Newfoundland Power’s load factor in 2020 was the highest recorded system load factor in at least 30 years and was influenced by public health measures in effect to manage the COVID-19 pandemic.

² Native peak is the maximum demand served by Newfoundland Power. The 2021 native peak reflects the winter period of December 2021 to 2022.