

- 1 **Q. (Reference Application, 4.2 Mobile Hydro Plant Refurbishment, Appendix A)**
2 **Would Newfoundland Power judge this project to be economic if the value of**
3 **system capacity were zero in 2024 and beyond?**
4
- 5 A. If the value of system capacity were zero in 2024 and beyond, the Mobile Hydro Plant
6 life cycle analysis would show the cost of production being less than the benefit
7 provided by export energy by 0.05 ¢/kWh. This net cost would indicate that the
8 continued operation of the plant remains economic.