

1 Q. **Reference: Schedule 6, Program 19 Overhaul Diesel Units (2024), Page 1, lines 13–17**

2 In establishing the criteria for overhauls, did Hydro consider the practice of other Canadian
3 utilities and is Hydro’s criteria consistent with Canadian utility practice?

4

5

6 A. Newfoundland and Labrador Hydro (“Hydro”) has discussed overhaul criteria with other
7 Canadian utilities. Most utilities use either 15,000 or 20,000 hours for 1,800 rpm unit overhauls
8 and either 30,000 or 40,000 hours for 1,200 rpm unit overhauls. This is consistent with Hydro’s
9 current overhaul criteria of 20,000 hours for 1,800 rpm units and 30,000 hours for 1,200 rpm
10 units.