

1 Q. Page 12, lines 4-5: Please provide a detailed breakdown of the estimated fuel
2 savings of \$0.73 million in 2016 and \$1.06 million in 2017.

3

4

5 A. Hydro operates the power system on the Avalon to be able to sustain acceptable
6 voltages and equipment ratings (up to a 25 MW overload following a disturbance)
7 resulting from the single largest contingency, typically the loss of either
8 transmission lines TL202 or TL206, or a unit at Holyrood. In other words, Hydro
9 carries sufficient Avalon reserves to be able to withstand the impact on the Avalon
10 as a result of the single largest contingency event.

11

12 In meeting this reliability objective, Hydro has determined, through load flow
13 analysis, Avalon loading thresholds to provide direction on when to staff and
14 operate the various standby resources on the Avalon.

15

16 To derive the benefit of the Holyrood diesels, Hydro developed an hourly Avalon
17 load forecast for the period of January 2016 to December 2017. As indicated in
18 Hydro's application, there are potential fuel savings for the Island Interconnected
19 System if the Holyrood diesels are used as part of the dispatch order for Avalon
20 reliability prior to the start-up of the Holyrood CT. This would mean fewer starts for
21 the CT and less run time (at a minimum load of 40 MW), as the diesels could be
22 started before the CT.

23

24 In its review of the analysis to determine the fuel savings presented in this
25 Application, Hydro discovered an error in that it assumed that 16 MW of diesel
26 generation would be available to supply the system from July 2016 to December
27 2017. However, only 10 MW should have been assumed for the entire analysis

1 period (January 2016 to December 2017). In addition, in the present configuration,
2 the base loading on the Holyrood diesel plant is 9,250 kW and not 1,000 kW as
3 assumed in the Application. Hydro has redone the analysis and a detailed
4 breakdown of the restated fuel savings of \$0.41 million in 2016 and \$0.50 million in
5 2017 are presented in Tables 1 and 2. As only the projected fuel savings from June
6 to December for 2016 were included in the CPW calculation, the savings in 2016
7 were reduced to \$0.15 million. The savings of \$0.50 million for the entire year 2017
8 were included.

9

10 This change in the fuel savings has the effect of changing the CPW from -\$0.254
11 million to \$0.426 million. Please see the revised CPW calculation in Table 3.

Procurement of 12 MW Diesel Generation at Holyrood (Revised)

Table 1					
<u>Jan - Dec 2016</u>					
Without Holyrood Diesels					
Standby Unit	Operating Hours	Minimum Load (MW)	Energy (kWh)	Rate (\$/MWh)	Cost (\$)
Hardwoods One End	340	5	1,700,000	\$ 0.21	\$ 357,000
Holyrood Diesels	-	9.25	-	\$ 0.19	\$ -
Holyrood CT	547	40	21,880,000	\$ 0.21	\$ 4,594,800
Hardwoods Two Ends	-	10	-	\$ 0.21	\$ -
Totals			23,580,000		\$ 4,951,800
With Holyrood Diesels					
Standby Unit	Operating Hours	Minimum Load (MW)	Energy (kWh)	Rate (\$/MWh)	Cost (\$)
Hardwoods One End	457	5	2,285,000	\$ 0.21	\$ 479,850
Holyrood Diesels	117	9.25	1,082,250	\$ 0.19	\$ 205,628
Holyrood CT	421	40	16,840,000	\$ 0.21	\$ 3,536,400
Hardwoods Two Ends	-	10	-	\$ 0.21	\$ -
Totals			20,207,250		\$ 4,221,878
Savings					
Gross Fuel Savings					\$ 729,923
Less Holyrood Replacement Energy Costs ¹					\$ (317,039)
Net Savings over Period					\$ 412,884
Note 1: The reduction in standby energy production (3,372,750 kWh) at Holyrood replacement costs \$0.094/kWh					

Procurement of 12 MW Diesel Generation at Holyrood (Revised)

Table 2					
Jan - Dec 2017					
Without Holyrood Diesels					
Standby Unit	Operating Hours	Minimum Load (MW)	Energy (kWh)	Rate (\$/MWh)	Cost (\$)
Hardwoods One End	351	5	1,755,000	\$ 0.22	\$ 386,100
Holyrood Diesels	-	9.25	-	\$ 0.19	\$ -
Holyrood CT	711	40	28,440,000	\$ 0.22	\$ 6,256,800
Hardwoods Two Ends	-	10	-	\$ 0.22	\$ -
Totals			30,195,000		\$ 6,642,900
With Holyrood Diesels					
Standby Unit	Operating Hours	Minimum Load (MW)	Energy (kWh)	Rate (\$/MWh)	Cost (\$)
Hardwoods One End	479	5	2,395,000	\$ 0.22	\$ 526,900
Holyrood Diesels	128	9.25	1,184,000	\$ 0.19	\$ 224,960
Holyrood CT	572	40	22,880,000	\$ 0.22	\$ 5,033,600
Hardwoods Two Ends	-	10	-	\$ 0.22	\$ -
Totals			26,459,000		\$ 5,785,460
Savings					
Gross Fuel Savings					\$ 857,440
Less Holyrood Replacement Energy Costs ¹					\$ (354,920)
Net Savings over Period					\$ 502,520
Note 1: The reduction in standby energy production (3,736,000 kWh) at Holyrood replacement costs \$0.095/kWh					

Procurement of 12 MW Diesel Generation at Holyrood (Revised)

Table 3 – Base CPW Calculation with Revised Fuel Savings

Purchase Diesels April 01, 2016 - Sell June 2020																
Discount		7.5%		CPW Date: Apr 01, 2016												
Rate																
	Diesel Purchase (,000s)	PW	Inter-connection Savings	PW	Fuel Savings	PW	Lease Savings	PW	EA Reg Cost	PW	O&M Cost	PW	Total PW	Diesel Resale Price	PW	CPW
2016	\$ 4,453	\$ 4,453	(\$480)	(\$469)	(\$151)	(\$146)	(\$360)	(\$356)	\$60	\$60	\$56	\$54	\$3,597			
2017					(\$503)	(\$460)					\$76	\$70	(\$389)			
2018											\$78	\$67	\$67			
2019											\$80	\$64	\$64			
2020											\$34	\$26	\$26	(\$4,068)	(\$2,938)	
													\$3,364		(\$2,938)	\$426